



FIRE SAFETY CERTIFICATE

Certified that the M/s Love Liquor Bar, running on ground floor located at Plot No. 9D, D - Block Aditya Mall, CBD Shahdara, Delhi - 110032, building comprised of ground plus one upper floor, owned/occupied by M/s Love Liquor Bar was issued Fire Safety Certificate vide letter No. F6/DFS/MS/EH/2021/NDZ/64 dated 11/03/2021. The building was re-inspected by the officer concerned of this department on 24/04/2024 in presence of Mr. Pankaj Kumar Singh (Owner) of the building and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and observed that the building is fit for occupancy class Group D "Assembly Building" Restaurant running at ground floor only up to 31.03.2027 i.e. for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, printed below.

Issued on 02/05/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24 w.e.f. - MHA portal ID - 2024040804460 dated 08/04/2024.
2. Mr. Pankaj Kumar Singh, M/s Love Liquor Bar, located at Plot No. 9D, D Block Aditya Mall, CBD Shahdara, Delhi-110032.

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for ground floor only
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/04

INSPECTION REPORT

| | | | | |
|-------------|---|---|-------------------------|-----------------------|
| 1 | Name & address of the building | M/s Love Liquor Bar, located at Plot No.9D Ground Floor, D Block Aditya Mall, CBD Shahdara, Delhi-110032. | | |
| 2 | Building is comprised of | Ground plus one floor but restaurant running on ground floor only. | | |
| 3 | Type of occupancy | Assembly (Restaurant) | | |
| 4 | Type of case | Renewal | | |
| 5 | Details of previous FSC | F6/DFS/MS/EH/2021/NDZ/64 dated 11/03/2021.(G+1) | | |
| 6 | Fire safety directives letter no. | NBC Part-IV | | |
| 7 | Date of inspection | 24.04.2024. | | |
| 8 | Name of the inspecting officers | Yashwant Singh Meena ADO (L.N) | | |
| 9 | Name of the designation of officer from the building side | Mr.Pankaj Kumar Singh (Owner) | | |
| 10 | Year of construction | 2017 | | |
| 11 | Applicant's letter no. | MHA Portal application No. I.D - 2024040804460 dated 08/04/2024 | | |
| S.No | Minimum standard of fire safety requirements as per circular no.262-362 dated 17.01.2005 | NBC Part-IV Requirement | Provided at site | Remarks MR/NMR |
| 1 | Access to Building: | | | |
| A | Road width | 9.0 mtrs. | 18 mtrs. ✓ | MR |
| B | Gate width | N/A | N/A | N/A |
| C | Width of internal road | N/A | 06 mtrs | MR |
| 2 | Number, Width, Type and Arrangement of Exits: | | | |
| A | Number of staircases | | | |
| a | Upper floor | 02 nos. | 02 nos. ✓ | MR |
| c | Basement | N/A | N/A | N/A |
| B | Width of staircases | | | |
| a | Upper floor | 2.0 mtrs & 1.50 mtrs | 2.0 mtrs & 1.50 mtrs ✓ | MR |
| b | Basement | N/A | N/A | N/A |
| C | Protection of exits | | | |
| a | Fire check door | Required | Provided | MR |
| b | Pressurization | N/A | N/A | N/A |
| D | No. of continuous staircases to terrace | N/A | N/A | N/A |
| E | Width of corridor | N/A | N/A | N/A |
| F | Door size | 2.0 mtrs. & 1.50 mtrs | 2.0 mtrs. & 1.50 mtrs ✓ | MR |
| g | No of Door | 02 nos | 02 nos ✓ | MR |
| 3 | Compartmentation: | | | |
| A | Fire check door | NA | NA | NA |
| B | Sealing of electrical shafts | N/A | N/A | N/A |
| C | Fire rating of shaft door | N/A | N/A | N/A |
| D | Water curtain | N/A | N/A | N/A |
| E | Fire dampers | N/A | N/A | N/A |
| 4 | Smoke Management System: | | | |
| A | Basement | N/A | N/A | N/A |
| B | Upper floor | N/A | N/A | N/A |

3

N/05

| | | | | |
|--|--------------------------------|-----------------------|-----------------------|-----|
| 5. Fire Extinguisher: | | | | |
| A | Total numbers | 04 nos. | 04 nos. | MR |
| B | Types | CO ₂ & ABC | CO ₂ & ABC | MR |
| C | ISI marking | ISI Marked | Provided | MR |
| 6 First-Aid-Hose Reel: | | | | |
| A | Total numbers of each floor | 1.0 mtr. | 1.0 mtr. | MR |
| B | Length of hose reel hose | 30 mtrs | 30 mtrs | MR |
| C | Nozzle diameter | 5 mm | 5 mm | MR |
| 7 Automatic Fire Detection and Alarming System: | | | | |
| A | Type of detectors | N/A | Smoke | MR |
| B | Location of main panel | N/A | N/A | N/A |
| C | Location of repeater panel | N/A | N/A | N/A |
| D | Alternate source of power | N/A | N/A | N/A |
| E | Hooters | N/A | N/A | N/A |
| 8 | MOEFA: | Required | Provided | MR |
| 9 | Public Address System: | N/A | N/A | N/A |
| 10 Automatic Sprinkler System: | | | | |
| A | Basement | N/A | N/A | N/A |
| B | Ground & Upper floor | N/A | Provided | MR |
| C | Sprinkler above false ceiling | N/A | N/A | N/A |
| 11 Internal Hydrants: | | | | |
| A | Size of riser/down-comer | 100 mm | 100 mm | MR |
| B | Number of hydrants per floor | 01 no | 01 no | MR |
| C | Hose box | 01 no | 01 no | MR |
| 12 Yard Hydrants: | | | | |
| A | Total number of hydrants | N/A | N/A | N/A |
| B | Hose box | N/A | N/A | N/A |
| 13 Pumping Arrangements: | | | | |
| 1 Ground level | | | | |
| A | Discharge of main pump | N/A | N/A | N/A |
| B | Head of main pump | N/A | N/A | N/A |
| C | Number of main pumps | N/A | N/A | N/A |
| D | Jockey pump out put | N/A | N/A | N/A |
| E | Jockey pump head | N/A | N/A | N/A |
| F | Standby pump out put | N/A | N/A | N/A |
| G | Standby pump head | N/A | N/A | N/A |
| H | Auto starting /manual stopping | N/A | N/A | N/A |
| I | Pump house access | N/A | N/A | N/A |
| 2 Terrace Level | | | | |
| A | Discharge of pump | 900 LPM | 900 LPM | MR |
| B | Head of the pump | 40 m | 40 m | MR |
| C | Power supply | Required | Provided | MR |
| D | Auto starting of pump | Required | Provided | MR |

M/s Love Liquor Bar, located at Plot No.9D Ground Floor, D Block Aditya Mall, CBD Shahdara, Delhi-110032.

W

NPO

**M/s Love Liquor Bar, located at Plot No.9D Ground Floor, D Block Aditya Mall,
CBD Shahdara, Delhi-110032**

| | | | | |
|-----------|---|---------------|---------------|-----|
| 14 | Captive Water Storage for Fire Fighting: | | | |
| A | Underground tank capacity | N/A | N/A | N/A |
| B | Draw-off connection | N/A | N/A | N/A |
| C | Fire service inlet | N/A | N/A | N/A |
| D | Access to tank | N/A | N/A | N/A |
| E | Overhead tank capacity | 20,000 liters | 20,000 liters | MR |
| 15 | Exit Signage: | Required | Provided | MR |
| 16 | Provision of Lifts: | | | |
| A | Pressurization of lift shaft | N/A | N/A | N/A |
| B | Pressurization of lift lobby | N/A | N/A | N/A |
| C | Communication in lift car | N/A | N/A | N/A |
| D | Firemen's grounding switch | N/A | N/A | N/A |
| E | Lift signage | N/A | N/A | N/A |
| 17 | Standby Power Supply: | Required | Provided | MR |
| 18 | Refuge Area: | | | |
| A | Total area | N/A | N/A | N/A |
| B | Location | N/A | N/A | N/A |
| 19 | Fire Control Room: | | | |
| A | Detector system panel | N/A | N/A | N/A |
| B | Flow switch panel | N/A | N/A | N/A |
| C | PA system panel | N/A | N/A | N/A |
| D | Battery backup | N/A | N/A | N/A |
| E | Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

Note: - Previous restaurant was running name of M/s Barshala (A unit of Insospirit Bars Pvt. Ltd.) at same address now owner and name of restaurant has been changed.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in NBC Part - IV, the FSC issued vide letter no. F6/DFS/MS/EH/2021/NDZ/64 dated 11.03.2021 is recommended to be renewed.



26/4/2024

Signature of the Inspecting Officer

Name: - Yashwant Singh Meena

Designation: - ADO (L.N)

~~DY. CFO/NDZ~~

Imp
29/04/24

~~C.F.O.~~

Naugh
30/4/2024

~~Director~~

1/05/24

AD/LN

Site F.T. letter is setup for sign. Please

~~Director~~

Uploaded
25/5/2024
03/5/24