



No. F6/DFS/MS/School/NDZ/2024/ 384

Dated: 03/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Kanya Vidyalaya at located Block -13, Geeta Colony, Delhi - 110031 comprised building of Ground plus three upper floors only (New Building) owned/occupied Sarvodaya Kanya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 22/04/2024 in the presence of Mr. Bhopal Singh (State Manager) and that the building /premises is fit for occupancy class "Educational Building" Group-B with effect from 03/05/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 03/05/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

**Copy to:-**

1. The Join Director of Education, (Land & Estate), Directorate of Education, Lucknow Road, Delhi-110054.
2. The Principal, Sarvodaya Kanya Vidyalaya, Block-13, Geeta Colony, Delhi-110031.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/23

**INSPECTION REPORT**

1	Name & address of the building	Sarvodaya Kanya Vidyalaya Located at Block - 13, Geeta Colony, Delhi - 110031.		
2	Building is comprised of	Ground plus three upper floors only. <b>(New Building)</b>		
3	Type of occupancy	Educational Building		
4	Type of case	New Case		
5	Details of previous FSC	Nill		
6	Fire safety directives letter no.	NBC Part-IV		
7	Date of inspection	22.04.2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Bhopal Singh (State Manager)		
10	Year of construction	2022		
11	Applicant's letter no.	Outdoor dairy No.82 dated 02/04/2024		
S.No	<b>Minimum standard of fire prevention and fire safety U/R 33</b>	<b>Requirement NBC Part -IV</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building:</b>			
	A	Road width	6.0 mtrs.	12 mtrs. ✓ MR
	B	Gate width	N/A	N/A
	C	Width of internal road	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
	A	Number of staircases		
		a	Upper floor	02 nos. 02 nos. ✓ MR
		b	Basement	N/A N/A N/A
	B	Width of staircases		
		a	Upper floor	1.50 mtrs. 1.50 mtrs each ✓ MR
		b	Basement	N/A N/A N/A
	C	Protection of exits		
		a	Fire check door	N/A N/A N/A
		b	Pressurization	N/A N/A N/A
	D	No. of continuous staircases to terrace	01 nos.	02 nos.each ✓ MR
	E	Width of corridor	1.50 mtrs.	1.50 mtrs. ✓ MR
	F	Door size	1.0 mtrs.	1.0 mtrs. ✓ MR
3	<b>Compartmentation:</b>			
	A	Fire check door	NA	NA ✓ NA
	B	Sealing of electrical shafts	N/A	N/A N/A
	C	Fire rating of shaft door	N/A	N/A N/A
	D	Water curtain	N/A	N/A N/A
	E	Fire dampers	N/A	N/A N/A
4	<b>Smoke Management System:</b>			
	A	Basement	N/A	N/A N/A
	B	Upper floor	N/A	N/A N/A

w

<b>5.</b>	<b>Fire Extinguisher:</b>				
	<b>A</b>	Total numbers	32 nos.	32 nos.	MR
	<b>B</b>	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	<b>C</b>	ISI marking	ISI Marked	ISI Marked	MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>				
	<b>A</b>	Total numbers of each floor	01 no	02 no each	MR
	<b>B</b>	Length of hose reel hose	30 mtrs	30 mtrs	MR
	<b>C</b>	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>				
	<b>A</b>	Type of detectors	N/A	N/A	N/A
	<b>B</b>	Location of main panel	N/A	N/A	N/A
	<b>C</b>	Location of repeater panel	N/A	N/A	N/A
	<b>D</b>	Alternate source of power	N/A	N/A	N/A
	<b>E</b>	Hooters	N/A	N/A	N/A
<b>8</b>	<b>MOEFA:</b>		N/A	Provided	MR
<b>9</b>	<b>Public Address System:</b>		N/A	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement	N/A	N/A	N/A
	<b>B</b>	Upper floor	N/A	N/A	N/A
	<b>C</b>	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	Size of riser/down-comer	100 mm	100 mm	MR
	<b>B</b>	Number of hydrants per floor	02 no	02 no	MR
	<b>C</b>	Hose box	02 no	02 no	MR
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	N/A	N/A	N/A
	<b>B</b>	Hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping Arrangements:</b>				
<b>1</b>	<b>Ground level</b>				
	<b>A</b>	Discharge of main pump	N/A	N/A	N/A
	<b>B</b>	Head of main pump	N/A	N/A	N/A
	<b>C</b>	Number of main pumps	N/A	N/A	N/A
	<b>D</b>	Jockey pump out put	N/A	N/A	N/A
	<b>E</b>	Jockey pump head	N/A	N/A	N/A
	<b>F</b>	Standby pump out put	N/A	N/A	N/A
	<b>G</b>	Standby pump head	N/A	N/A	N/A
	<b>H</b>	Auto starting /manual stopping	N/A	N/A	N/A
	<b>I</b>	Pump house access	N/A	N/A	N/A
<b>2</b>	<b>Terrace Level</b>				
	<b>A</b>	Discharge of pump	450 LPM	450 LPM x 2	MR
	<b>B</b>	Head of the pump	40 mtrs.	40 mtrs.	MR
	<b>C</b>	Power supply	Required	Provided	MR
	<b>D</b>	Auto starting of pump	Required	Provided	MR

<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	Required	Provided	MR
E	Overhead tank capacity	10,000 liters.	10,000 liters. ✓	MR
<b>15</b>	<b>Exit Signage:</b>			
		Required	Provided	MR
<b>16</b>	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
<b>17</b>	<b>Standby Power Supply:</b>			
		N/A	N/A	N/A
<b>18</b>	<b>Refuge Area:</b>			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
<b>19</b>	<b>Fire Control Room:</b>			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			
		N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 37 of Delhi Fire Service Rules 2010

**No file is pending with me before disposal of this case.**

*[Signature]*  
26/4/2024

Signature of the Inspecting Officer  
Name- Yashwant Singh Meena  
Designation- ADO (L.N)

~~DYCFO (NDZ)~~

*Imp*  
*29/04/24*

*C.F.O.*  
*30/4/2024*

*Director*  
*[Signature]*

*Author*

Sir, F.T letter is put up for sign. Please  
Director *[Signature]*

*[Signature]*  
2/5/2024