

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2024 /378

Dated: 02/05/2024

FIRE SAFETY CERTIFICATE

Certified that the **Arya Girls Senior Secondary School, Teliwara, Delhi - 110006**, building is divided into two separate blocks & comprised of **Ground + 02 upper floors**, but school is running at **ground plus one upper floor**. The premises was inspected by the officer concerned of this department on 22.04.2024 in the presence of Mrs. Madhu Sharma (H.O.S.) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 that the building is fit for occupancy of **(Class-B) "Educational Building" ground plus one upper floor only**, with effect from02/05/2024..for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on02/05/2024.....at New Delhi by


 (Atul Garg)
 Director
 Delhi Fire Service
 Tel: 011-23414000
 01/2
 30/04

Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Arya Girls Senior Secondary School, Teliwara, Delhi - 110006.

Conditions for the validity of Fire Safety Certificate


1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name and address of the building:	Arya Girls Senior Secondary School, Teliwara, Delhi - 110006.
2	Type of occupancy with details of floors:	Educational Building (Group-B) Building is divided into two separate blocks: Ground + 02 upper floors (But school is running at ground + 01 upper floor only & both blocks interconnected at 1 st floor)
3	Type of case:	New
4	Details of previous FSC:	NA
5	Fire safety directives no.:	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
6	Date of inspection:	22.04.2024
7	Name of the inspecting officer:	Sumit Kumar, ADO (SPM)
8	Name and designation of the officer from the building side:	Mrs. Madhu Sharma (H.O.S.)
9	Year of construction:	1909
10	Reference letter no.:	Letter no. 07/2024-25 dated 12.04.2024

S. No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	As per Education Circular dated 01.03.2011	Provide at site	Remarks MR/NM R
1	Access to Building			
	A	Road width	06 mtr.	Approachable to fire unit with 30 mtr. length of hose MR
	B	Gate width	NA	NA
	C	Width of internal roads	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	A	No. of Staircase:		
		a) Upper floor	02 nos.	02 nos. MR
		b) Basements	NA	NA
	B	Width of the Staircase:		
		a) Upper floor	150 cms. & 75 cms.	105 cms. & 100 cms. MR
		b) Basements	NA	NA
	C	Protection of Exits		
		a) Fire check door	NA	NA NA
		b) Pressurization	NA	NA NA
	D	No. of continuous staircase to terrace:	1 nos.	1 nos. MR
	F	Width of the corridor	NA	NA
	E	Door size	1.0 mtr.	1.0 mtr. MR
3	Compartmentation:			
	A	Fire check doors	NA	NA NA
	B	Sealing of electrical shafts	NA	NA NA
	C	Fire rating of shaft doors	NA	NA NA
	D	Water curtain	NA	NA NA
	E	Fire dampers	NA	NA NA
4	Smoke management System:			
	A	Basements	NA	NA NA
	B	Upper floors	12 ACPH	Natural MR
5	Fire extinguishers			
	A	Total numbers	08 nos.	08 nos. MR
	B	Types	ABC & Co2	ABC & Co2 MR
	C	ISI marking	Required	Provided MR

6	First Aid Hose reel				
	A	Total no. at each floor	NA	NA	NA
	B	Length of Hose Reel	NA	NA	NA
	C	Nozzle diameter	NA	NA	NA
7	Automatic Fire Detection and Alarm System (ADAS)				
	A	Type of Detectors	NA	NA	NA
	B	Location of main Panel	NA	NA	NA
	C	Location of Repeater Panel	NA	NA	NA
	D	Alternate power Source	NA	NA	NA
	E	Hooter's location	NA	NA	NA
8	MOEFA				
9	Public Address System				
10	Automatic Sprinkler System				
	A	Basement	NA	NA	NA
	B	Upper Floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal hydrants				
	A	Size of the riser/down comer	NA	NA	NA
	B	No. Of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping arrangements				
	A	Ground Level			
		a) Discharge of main pump	NA	NA	NA
		b) Head of main pump	NA	NA	NA
		c) Number of main pump	NA	NA	NA
		d) Discharge of jockey pump	NA	NA	NA
		e) Head of jockey pump	NA	NA	NA
		f) Discharge of Standby pump	NA	NA	NA
		g) Head of Standby pump	NA	NA	NA
		h) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	NA	NA	NA
		b) Head of terrace pump	NA	NA	NA
		c) Alternate power supply	NA	NA	NA
		d) Auto starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire Service Inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	NA	NA	NA
15	Exit Signage				
16	Provision of lift		Required	Provided	MR
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply				
			NA	NA	NA

Se

 501

18	Refuge Area			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room			
A	Fire Detection System panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any:			NA

The Fire Protection System provided in the school were tested, checked and random and found functional at the time of inspection.

The school building is divided into two separate blocks & both blocks interconnected at 1st floor of the building. Each block comprises of ground plus two upper floors, but school is running at ground plus one upper floor at the time of inspection & as per affidavit dated 12.04.2024. The two blocks have 02 staircase (one each in a block) having width of 105 cms & 100 cms respectively.

Keeping in view the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under Directorate of Education Circular No. 3298-3398 dated 01.03.2011, it is recommended to issue Fire Safety Certificate under Rule 35(3) of the Delhi Fire Service Rules, 2010.

*Sir, no other file is pending with me, before disposal of this file.

[Signature]
25/04/2024

Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (CD)

[Signature]
25/4/24

[Signature]
Dy. Insp. (CD 2)

[Signature]
26/04/24

C.F.O.
[Signature]
29/4/2024

Director
[Signature]
29/04/24

[Signature]

F.T. letter is put up for signature, please.

[Signature]
30/04/2024

Director (DFE)
[Signature]
1/5/24