

3-30

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2024/School/374

Dated: 01/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of M.C. D Primary School (School ID – 1757163) Block B & Block C Located at Mahavir Enclave Part II/III/1<sup>st</sup> New Delhi comprised of block B Ground + 02 Upper Floor & Block C comprised of G + 01 UF was issued Fire Safety Certificate by this department vide Letter No. F.6/DFS/MS/School/2020/SZ/17 dated 23/10/2020. The premises was re inspected by the officer concerned of this department on 16/04/2024 in the presence of Smt. Nutan (Principal). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class B "Educational" with effect from 01.05.2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01.05.2024..... at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, M.C. D Primary School (School ID – 1757163) Block B & Block C Located at Mahavir Enclave Part II/III/1<sup>st</sup> New Delhi.

**Following fire safety directives must be adhered to:-**

1. Block A comprised of Ground plus two upper floors located in the premises shall not be used for school activities without getting FSC from this department.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. Basement shall be used strictly as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).




## INSPECTION REPORT

n-21

1. Name & address of the building: M.C. D Primary School (School ID - 1757163) Block B & Block C Located at Mahavir Enclave Part II/III/1<sup>st</sup> New Delhi.
2. Type of Occupancy : Educational 2 Blocks (BL B- G+2UF) & (BL=C- G+1UF Only) (BL-B & C interconnect)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2020/SZ/17 Dated 23/10/2020
5. Fire Safety directives Letter No. : Circular. No 3298-3398, dated 01/03/2011
6. Date of inspection : 16/04/2024
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer  
from the building side : Smt. Nutan (Principal)
9. Year of Construction : 2003 & 2008
10. Applicant's letter No. : Email Dated - 22/03/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/12, N/13 & N/14	Provided at site	Remarks MR/NMR
1.	Access of building	06 mtrs	Provided	MR
	• Road width	4.5mtrs	Directly accessible from road	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	BL-A=2& BL-B&C =One each	Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 mtr,	Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	Required	One	MR
	d. No of continuous staircase to terrace	1.5 mtr	Provided	MR
	e. Width Of Corridor	01 mtr	Provided	MR
	f. Door Size			
3.	Compartmentation	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System	NA	NA	NA
	• Basements	12 a/c per hour	Natural ventilation	MR
	• Upper floors			



5.	Fire Extinguishers				
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	02 nos.each floor ABC & CO <sub>2</sub> ISI marked	13 Nos.	MR	
			Provided	MR	
			ISI marked	MR	
6.	First – Aid Hose Reels				
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 30 mtr 5 mm	Provided 30 mtr 5 mm	MR MR MR	
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
8.	MOEFA	NA	NA	NA	NA
9.	Public Address System	NA	NA	NA	NA
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
11.	Internal Hydrants:				
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
12.	Yard Hydrants				
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
13.	Pumping Arrangements:				
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		450 lpm	Provided	MR	
		40 mtr	40 mtr	MR	
		Required	Provided	MR	
		Required	Provided	MR	
14.	Captive water Storage for fire fighting:				
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		10,000 ltr	Provided	MR	
15	Exit Signage	Required	Provided	MR	



16. Provision of Lifts				
➤	Pressurization of Lift Shaft	NA	NA	NA
➤	Pressurization of lift lobby	NA	NA	NA
➤	Communication in lift Car	NA	NA	NA
➤	Fireman's Grounding Switch	NA	NA	NA
➤	Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18. Refuge Area				
➤	Total area	NA	NA	NA
➤	Location	NA	NA	NA
19. Fire control room				
➤	Detector system panel	NA	NA	NA
➤	Flow Switch Panel	NA	NA	NA
➤	PA System Panel	NA	NA	NA
➤	Battery backup.	NA	NA	NA
➤	Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.  
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F.6/DFS/MS/School/2020/SZ/17 Dated 23/10/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved FSC may be issued.

Signature of the Inspecting Officer  
 Name Uday Vir Singh  
 Designation Asst. Insp.

no/sto  
at  
CF/22  
22/11/2021  
Director  
27/11/21  
Mus

Asst. Insp.