

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2024/SZ/397

Dated: 06/05/2024

FIRE SAFETY CERTIFICATE

Certified that **The Shri Ram School** located at **D-3, Street, Vasant Vihar, New Delhi-110057** comprised of Basement, Ground plus two upper floor and Ground plus 03 upper floor, both blocks are interconnected owned/occupied by The Shri Ram school was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2021/SZ/193 Dated 08/03/2021. The said premises was re-inspected by officer concerned of this department on 25/04/2024 in the presence of Ms. Pooja Thakur (Principal Jr. School) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **“Educational Building Group - B”** with effect from 06/05/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 06/05/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Shri Ram School located at D-3, Street, Vasant Vihar, New Delhi-110057
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/96

INSPECTION REPORT

| | | | | |
|--------|---|--|----------------------|----------------|
| 1 | Name & Address of the Building | The Shri Ram School, D-3, Street Vasant Vihar, New Delhi 110057. | | |
| 2 | Type of Occupancy | Educational Building | | |
| 3 | Building Comprised of | 1 st block (B+G+2) & 2 nd block (G+3) interconnected block | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/DFS/MS/School/2021/SZ/193 Dated 08/03/2021 | | |
| 6 | Fire Safety Directives Letter No | NBC Part IV | | |
| 7 | Date of Inspection | 25-04-2024 | | |
| 8 | Name of the Inspecting Officers | DO (South) & ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Ms. Pooja Thakur | | |
| 10 | Year of construction | 1995 | | |
| 11 | Applicant letter No. | Outdoor diary no 14665 Dated 27/03/2024 | | |
| S. No. | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC dt 14/01/2015 | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | • Road width | Required | 9 mtr | MR |
| | • Gate width | Required | 4.5 mtr | MR |
| | • Width of internal road | -NA- | -NA- | -NA- |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors. | 02 No | Provided | M/R |
| | ➤ Basement floor. | 02 No | Provided | M/R |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | 1.50 mtr | 1.50 mtr each | M/R |
| | ➤ Basement floor | 1.50m | 1.50m each | MR |
| | c) Protection of exits | | | |
| | ➤ Fire check door | -NA- | -NA- | -NA- |
| | ➤ Pressurization | -NA- | -NA- | -NA- |
| | d) No. of continuous staircase to terrace | Required | One | MR |
| | e) Width of corridor | 1.50m | 1.50 mtr | MR |
| | f) Door size | 01 m | 01 m | M/R |
| 3 | Compartmentation. | | | |
| | • Fire check door. | -NA- | -NA- | -NA- |
| | • Sealing of electrical shafts. | -NA- | -NA- | -NA- |
| | • Fire rating of shaft door. | -NA- | -NA- | -NA- |
| | • Water curtain | -NA- | -NA- | -NA- |
| | • Fire dampers. | -NA- | -NA- | -NA- |
| 4 | Smoke Management system. | | | |
| | • Basement | 30 ACPH | Exhaust fan provided | MR |
| | • Upper floors | 12 ACPH | -NA- | -NA- |
| 5 | Fire Extinguishers. | | | |
| | • Total numbers | | 30 Nos- | MR |
| | • Types | | ABC & CO2 | MR |
| | • ISI Marking | ISI mark | Provided | MR |
| 6 | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | 02 at each | Provided | M/R |
| | • Length of hose-reel hose. | 30 m | Provided | M/R |
| | • Nozzle Diameter | 5 mm | Provided | M/R |
| 7 | Automatic fire detection & alarming system. | | | |
| | • Type of detectors | -NA- | -NA- | -NA- |
| | • Location of Main Panel | -NA- | -NA- | -NA- |

N

N/27

| | | | | |
|-----|---|-----------|------------|------|
| | <ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooter's location | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 8 | MOEFA | -NA- | NA | -NA- |
| 9 | Public Address System | Required | Provided | MR |
| 10 | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling | Required | Provided | MR |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 11 | Internal Hydrants. | | | |
| | <ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. | -NA- | 100 mm | -NA- |
| | | -NA- | 02 Nos | -NA- |
| | | -NA- | 02 Nos | -NA- |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants. Hose box. | -NA- | 07nos | -NA- |
| | | -NA- | 07 nos | -NA- |
| 13 | Pumping arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. | -NA- | 900 LPM | -NA- |
| | | -NA- | 40 m | -NA- |
| | | -NA- | One | -NA- |
| | | -NA- | 180 LPM | -NA- |
| | | -NA- | 40 | -NA- |
| | | -NA- | 900 KPM | -NA- |
| | | -NA- | 40 m | -NA- |
| | | -NA- | Provided | -NA- |
| | | 450 LPM | Provided | MR |
| | | 40 mtr | 40m | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| 14 | Captive water storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. | -NA- | 50,000 ltr | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | 5,000 Ltr | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 17 | Standby Power Supply | -NA- | Provided | -NA- |
| 18 | Refuge Area | | | |
| | <ul style="list-style-type: none"> Total area Location | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 19. | Fire Control Room. | | | |
| | <ul style="list-style-type: none"> Detector system panel. Flow switch panel. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |

n/28

| | | | | |
|-----|--|------|------|------|
| | PA system panel. | -NA- | -NA- | -NA- |
| | Battery backup. | -NA- | -NA- | -NA- |
| | Building floor plan. | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | | | -NA- |

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2021/SZ/193 Dated 08/03/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Signature]
30/4/2024

[Signature]
Signature of the Inspecting Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)

[Signature]
21/5/2024
[Signature]
21/5/24
[Signature]

[Signature]
ADDO/BLO

As approved, F.T. letter is put up for
your signature Pl

[Signature]
06/5/24

[Signature]
Director
C/S/mr
[Signature]