

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No. F.6/DFS/MS/Industry/2024/SZ/ 279

Dated: 06/05/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Stanvac Prime Private Limited, B-100, Rewari Line Industrial Area-I, New Delhi-110064, comprised of two-tier basement, stilt, ground floor plus two upper floors owned/occupied by M/s Stanvac Prime Private Limited has already issued FSC by this department vide letter No. F6/DFS/MS/Industry/2021/SZ/19 dated 12.02.2021. The premises was re-inspected by the officer concerned of this department on 23.04.2024 in the presence of Sh. Dharambir Singh (Admin.) and found that the building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy Moderate Hazard[G-2(B-iii)] storage of Ethyl Neutral Alcohol with effect from 06/05/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 06/05/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. M/s Stanvac Prime Pvt. Ltd., B-100, Rewari Line Industrial, Area-I, New Delhi-64.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. **The Correct labeling of Ethyl Neutral Alcohol be followed.**
6. Ethyl Neutral Alcohol storage not allowed more than 30,000 liters
7. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
8. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
9. Basement shall be used as per the building bye laws.
10. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
11. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/32

INSPECTION REPORT

1. Name & address of the building : M/s Stanvac Prime Private Limited, B-100, Rewari Line Industrial Area-I, New Delhi-110064.
2. Building Comprised of : two tier Basement, Stilt, ground floor plus two upper floors
3. Type of Occupancy : Industrial
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/Industry/2021/SZ/19 dated 12.02.2021
6. Fire Safety directives letter No : F6/DFS/MS/BP/2016/190 dated 12.08.2016 & F6/DFS/MS/BP/2018/192 dated 15.06.2018
7. Date of inspection : 23.04.2024
8. Name of Inspecting Officer : A.D.O. R.K.Yadav (JKP)
9. Name and designation of officers
From the building side : Sh. Dharambir Singh (Admin.)
10. Year of Construction : Before 2018
11. Applicant's letter No. : Nil dated 27.03.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL-16 Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtrs 05 mtrs N/A	Provided Provided N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 No's	Provided	M/R
	• Basements	02 No's	Provided	M/R
	b. Width of staircases			
	• Upper Floor	1.50 m each	1.50 m (02 no.'s)	M/R
	• Basements	1.50 m each	1.50 m (02 no.'s)	M/R
	c. Protection of exits			
	• Fire check door	Required	Provided	M/R
	• Pressurization	Required	Provided	M/R
	d. No. of continuous staircases to terrace	02 No's	02 No's	M/R
		Required	Provided	M/R
	e. Width of Corridor	1.50 M	Provided	M/R
	f. Main Door Size	1.50 M	Provided	M/R
3.	Compartmentation			
	• Fire check door	Required	Provided	M/R
	• Sealing of electrical shafts	Required	Sealed	M/R
	• Fire Rating of shaft door	Required	Provided	M/R
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	Required	Mechanical ventilation system is provided	M/R
	• Upper floors	Required	Provided	M/R
5.	Fire Extinguishers			
	• Total numbers	04 no.'s/floor	Provided	M/R
	• Types	W/CO ₂ / CO ₂ type	Provided	M/R
	• IS marking	ISI marked	Provided	M/R


W/33


6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Two 30 m 5 mm	Provided Provided Provided	M/R M/R M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors (Smoke /Heat) Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required Required N/A Required Required	Provided Provided N/A Provided At exits	M/R M/R N/A MR MR
8.	MOEFA	Required	Provided	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor & upper floors Sprinkler above false ceiling 	Required Required N/A	Provided Provided N/A	M/R M/R N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 MM Two Two	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required Required	06 no.'s Provided 06 no.'s Provided	MR MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	2280 LPM 70 mtrs One 180 LPM 70 mtrs 2280 LPM 70 mtrs Required Required 450 LPM 40 mtrs Required Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR MR MR MR MR M/R M/R M/R M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	1,50,000 ltrs Required Required N/A 25,000 ltrs	Provided Provided Provided N/A Provided	M/R M/R M/R N/A M/R
15.	Exit Signage.	Required	Provided	M/R


16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	Required	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	M/R
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	CO ₂ fire extinguishers are provided for electrical panel	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.


Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC was issued vide letter no. F6/DFS/MS/Industry/2021/SZ/19 dated 12.02.2021, renewal under the Rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

DO (SW) 
25/4/24

CFO (SZ) 
26/4/2024

Director


26/4/24
ADO/JKP