

C-15



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/EH/120

Dated 01/05/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Flavours Family Restaurant located at Plot No.6, Ground Floor, Bhamra Shah Marg, Opp. Kripal Bagh Ashram, Near Model Town, Delhi-110009 in the building comprised of basement, ground & 03 upper floors only owned/ occupied by Sh. Arpit Bindal have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 18.04.2024 in the presence of Sh. Santosh (Manager) and that the building/ premise is fit for occupancy "Group D" Assembly (Restaurant) for ground floor only with effect from 01/05/2024 for a period of 03 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...01/05/2024... at New Delhi by

(Atul Garg)
Director
Ph-011-23414000
etc

Copy to:-

1. M/s Flavours Family Restaurant located at Ground Floor, 6, Bhamra Shah Marg, Opp. Kripal Bagh Ashram, Near Model Town, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. This Fire Safety Certificate is valid only for restaurant at ground floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
4. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of firefighting system.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Flavours Family Restaurant located at GF, 06, Bhamra Shah Marg Opp. Kripal Bagh Ashram, Near Model Town, Delhi-110009.
2. Type of Occupancy : Assembly/ Restaurant
3. Composition of building : Basement & 03 upper floors, But restaurant proposed at ground floor only
4. Type of Case : New
5. Details of previous NOC : F6/DFS/MS/GH/2021/476 Dated: 22.10.2021 for Guest house at ground & 03 Upper floors Only & F6/DFS/MS/2023/97 Dated: 10.03.2023 for fun melon kids gym in Basement
6. Fire Safety directives letter No : NBC Part IV
7. Date of inspection : 18.04.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Santosh (Manager)
10. Year of Construction : 2004
11. Applicant's letter No. : Online MHA Portal ID No-2024041004667 dated: 13.04.2024

| | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Part IV Requirements | Provided at site | Remarks MR/NMR |
|----------------------|---|--------------------------|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 06m | 08m approx.. | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| e. Width of Corridor | NA | NA | NA | |
| f. Door Size | 1.50m each | 1.70m & 1.60m each | MR | |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors (Ground floor) | Required | Provided | MR |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 04nos | 04nos, | MR |
| | • Types | ABC & Co2 | ABC - 04 | MR |
| | • ISI marking | Yes | Yes | MR |
| 6 | First-Aid Hose Reels. | | | |


RP

| | | | | |
|----|---|--|--|--|
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 01 30m 5mm | 01 30m 5mm | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA NA NA NA NA | Provided NA NA NA NA | NA NA NA NA MR |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling | NA NA NA | NA Provided NA | NA NA NA |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | 100mm 01 01 | Provided 01 01 | MR MR MR |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA NA | NA NA | NA NA |
| 13 | Pumping Arrangements also connected with Grand Venizia Guest House fire systems; as per fire safety directives issued to guest house vide letter no.F6/DFS/MS/GH/2011/726 dated 21.04.2011 | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | 1600 LPM 40m N/A N/A 1600 LPM 40m N/A N/A | 1600 LPM 40m N/A N/A 1600 LPM 40m N/A N/A | MR MR N/A N/A MR MR N/A N/A |
| | | 900 LPM 40m Required Required | 900 LPM 40m Provided Provided | MR MR MR MR |
| 14 | Captive Water Storage for firefighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | 1,00,000 LTR NA NA NA 20,000 LTR | 1,00,000 LTR NA NA NA Provided | MR NA NA NA MR |
| 15 | Exit Signage. | Required | Provided | MR |

| | | | | |
|----|--|----------|----------|-----|
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |


Note:-

- All the fire safety arrangements connected with Grand Venizia Guest House.
 - The total covered area of the basement is 129sqm (Approx) including seating area, toilet area, play area,
 - As per the NBC Part IV, the number of occupants comes out to be approx 72 person's i.e. $(129/1.8=72)$
- The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection.
- Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.



 Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation :- ADO/RN


Dy. Chief Fire Officer (WZ)


22/04/2024


 22/4/2024
 Entry & Exit including staircases are not connected to Restaurant. Also their segregation is to be employed.

of Guest house cabins


 Dy. C.F.O (WZ)


 22/4/


 ADO (RN)

Cont. P.T.O -