

c 21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No: F.6/DFS/MS/School/WZ/2024/ 405

Dated: 08/05/2024

**FIRE SAFETY CERTIFICATE**


Certified that the **Guru Angad Public School**, Located at **NW-157, Vishnu Garden, New Delhi-110018** is running at ground + 01 upper floor only in a building comprised of Ground + three upper floors. was issued FSC by this department vide letter No. F6/DFS/MS/School/2018/481 dated 22/03/2018. The premises was re - inspected by the officer concerned by this department on 18/04/2024 in the presence of Sh. S.S. Walia (Owner) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with the DOE circular no.F6/Estate/Fire/safety/2011/3298-3398 dated 01/03/2011 and that the premises is fit for occupancy class "**Educational**" (**Group-B**), (**Ground and First floor Only**) with effect from 08/05/2024.....for a period of three years. Condition mentioned below.

Issued on 08/05/2024 at New Delhi.

  
(Atul Garg)  
Director

Copy to: -

1. The Owner/occupier, Guru Angad Public School, Located at NW-157, Vishnu Garden, New Delhi-110018.
2. The Director, Directorate of Education, old secretariat, Delhi

  
02/5/2024

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. **Second and third floor will not be used for any purpose, if it is used FSC shall null & void automatically.**



118  
**INSPECTION REPORT**

1. Name & address of the building	Guru Angad Public School, Located at NW-157, Vishnu Garden, New Delhi-110018.
2. Type of Occupancy	Educational (Ground + 1)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/2018/481 dated 22/03/2018
5. Fire Safety directives letter No	DOE Circular dated 01/03/2011
6. Date of inspection	18/04/2024
7. Name of the Inspecting Officers	Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side	Sh. S.S. Walia (owner)
9. Year of Construction	2005 (As per previous insp. dated – 09/03/2018)
10. Applicant's letter No.	Letter dated 27/03/2024, outdoor diary no.14663 dated 27/03/2024

\* The said building is comprised of Ground + 03 upper floors but school is running on Ground & 1<sup>st</sup> floor only.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	01	02 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts	0.80m x 2 Provided	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1 m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	05	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA

22



7	<b>Automatic fire detection and alarming system.</b>			NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>			NA
9	<b>Public Address System.</b>			NA
10	<b>Automatic Sprinkler System.</b>			NA
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			NA
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			NA
	• Ground Level			NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			NA
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	<b>Exit Signage.</b>			NA
16	<b>Provision of Lifts.</b>			NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>			NA

18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC/FSC issued vide letter no. F6/DFS/MS/WZ/2020/school/154 dated: 13/04/2020 renewal under DOE 3298-3398 dated 01/03/2011 is recommended.

ADOMN  
104/2024

*ADOMN*

*[Signature]*  
19/4/2024

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADOMN

Let me know, any previous file is pending with you or not.

ADOMN

*[Signature]*  
19/4

no pending sir

re-submitted no.

FOI 22/.....  
Dated 19/04/2024

*ADOMN*

*[Signature]*  
26/4/2024

*[Signature]*  
29/4

FOI 22/.....  
29/04/2024

*[Signature]*  
29/4/2024

*[Signature]*  
*[Signature]*

*[Signature]*

*[Signature]*