



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F.6/DFS/MS/School/2024/SZ/ 398

Dated: 07/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **M.B.D.A.V. Senior Secondary School, Yusuf Sarai, New Delhi-110016** (ID: 1925199), comprised of three independent blocks, one block of G+1 upper floor & two blocks each of G+2 upper floors, but the school running at ground & first floor only, have complied with the fire prevention and fire safety requirement in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officers concerned of this department on 22/04/2024 in the presence of Sh. R.S. Panwar (Sr. Teacher) & Sh. Neeraj Gulati (ASO) and that the school building/premises is fit for occupancy class "**Educational**" (Group 'B') with effect from 07/05/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/05/2024 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Principal, M.B.D.A.V. Senior Secondary School, Yusuf Sarai, New Delhi-110016
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times as seen during inspection. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

### INSPECTION REPORT

1.	Name & address of the building	M.B.D.A.V. Senior Secondary School, Yusuf Sarai, New Delhi-110016 (ID: 1925199)		
2.	Type of Occupancy	Educational Group-B (School)		
3.	Building Comprised of	There are three independent blocks, one block of G+1 upper floor & two blocks each of G+2 upper floors. But the MBDAV School is running in blocks up to first floor only. 2 <sup>nd</sup> floor of the buildings is not used by MBDAV school.		
4.	Type of Case	New		
5.	Details of previous NOC No.	Nil		
6.	Fire Safety directives Letter No.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
7.	Date of inspection	22/04/2024		
8.	Name of the Inspecting Officer	Manoj Kumar Sharma (DO/SD) and Santosh Kumar (ADO/SJ)		
9.	Name and designation of Officer from the building side	Sh. R.S. Panwar (Sr. Teacher) Sh. Neeraj Gulati (ASO)		
10.	Year of Construction	Ph-I=1339, Ph-II=1947-48, Ph-III=1950-51		
11.	Applicant's letter No.	Outdoor Diary No. 13947 dated 06/03/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular Dt. 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	6m NA NA	Provided 4m NA	MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	One each blk NA	G+1=1, G+2=2 + 2 (iron) NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	1.5m/0.75m NA	G+1=1.5 & G+2=1.5m, 1.5m, 1.1m & 1m NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	NA	Two	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI marking</li> </ul>	10 Nos ABC/CO <sub>2</sub> ISI Marked	15 Nos ABC & CO <sub>2</sub> Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	NA NA NA	NA NA NA	NA NA NA

8

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

*SK*

*W*

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE Circular dated 01.03.2011, issue of Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Manoj*  
 Signature of the Inspecting Officer  
 Name: Manoj Kumar Sharma  
 Designation: DO (SD)

*Santosh*  
 Signature of the Inspecting Officer  
 Name: Santosh Kumar  
 Designation: ADO (SJ)

CFO (HQ) *Hugh*  
 2/27/2014  
Director *[Signature]*  
 2/15/14

*Adv/SJ*

Sir,  
 F.T letter is put up for your sig. pl

Director *[Signature]*  
 4/9/14  
*[Signature]*

*Santosh*  
 06/05/24