



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/EH/2024/SZ/ 119

Dated: 01/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Dragonfly** (A unit of First Fiddle F & B Pvt. Ltd), RT LGF R-5, Lower Ground Floor, Worldmark-1, Aerocity, IGI Airport, New Delhi-110037, comprised of Three Basements, Ground, Mezzanine + 06 upper floors but the restaurant running at Lower Ground Floor only, owned/occupied by A unit of First Fiddle F & B Pvt. Ltd, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/SZ/2021/176 dated 10/08/2021. The said restaurant was re-inspected by the officers concerned of this department on 25/04/2024 in the presence of Mr. Ravinder Singh of the restaurant and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said premise is fit for occupancy class "Assembly Group D" (Eating House) up to 31/03/2027 in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/05/2024 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
of do

Copy to:-

1. The Joint Commissioner of Police, Licensing Branch, First Floor, Police Station Defence Colony, New Delhi-110049 (w.r.t. MHA ID No. 2024041305027 dated 13/04/2024)
2. Mr. Amit Sudan M/s Dragonfly (A unit of First Fiddle F & B Pvt. Ltd) at RT LGF R-5, Lower Ground Floor, Worldmark-1, Aerocity, IGI Airport, New Delhi-110037

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its

### INSPECTION REPORT

1	Name & Address of the Building	M/s Dragonfly (A unit of First Fiddle F & B Pvt. Ltd), RT LGF R-5, Lower Ground Floor, Worldmark-1, Aerocity, IGI Airport, New Delhi-110037		
2	Type of Occupancy	Assembly 'Group-D' (Restt. at LG Floor)		
3	Building comprised of	03 Basements, Mezzanine, Ground + 06 floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/SZ/2021/176 dated 10/08/2021		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2017/Hotel/368 dated 21/02/2017		
7	Date of Inspection	25/04/2024		
8	Name of the Inspecting Officers	Manoj Kumar Sharma (DO/SD), Santosh Kumar (ADO/SJ)		
9	Name & Designation of Officers from the building side	Mr. Ravinder Singh		
10	Year of construction	2014		
11	Applicant letter No.	MHA ID No. 2024041305027 dated 13/04/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building	FSC No F.6/DFS/MS/Mixed/2024/SZ/HTL/12 dated 12/03/2024		
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Restt located within Worldmark-I	<ul style="list-style-type: none"> <li>As above</li> <li>As above</li> <li>As above</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>N/A</li> <li>N/A</li> </ul>
2	<b>Number, width, type &amp; arrangement of exits</b>			
	a. Number of Staircase	Provided & Maintained by Building Mgmt.		
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basement floor/Lower GF</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>02 Nos</li> </ul>	<ul style="list-style-type: none"> <li>As above</li> <li>As above</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>MR</li> </ul>
	b. Width of Staircase	Provided & Maintained by Building Mgmt.		
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basement floor/Lower GF</li> </ul>	<ul style="list-style-type: none"> <li>N/A</li> <li>2m/1.35m</li> </ul>	<ul style="list-style-type: none"> <li>As above</li> <li>1.6m each + 7.5m ramp</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>MR</li> </ul>
	c. Protection of exits	Provided & Maintained by Building Mgmt.		
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>As above</li> <li>As above</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>
	d. No. of continuous staircase to terrace	Required		
	e. Width of corridor	-NA-		
	f. Door size	2m / 1.35m      2m, 1.65m & 1.40m		
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door.</li> <li>• Sealing of electrical shafts.</li> <li>• Fire rating of shaft door.</li> <li>• Water curtain</li> <li>• Fire dampers.</li> </ul>	<ul style="list-style-type: none"> <li>Required</li> <li>Required</li> <li>Required</li> <li>Required</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>As above</li> <li>As above</li> <li>As above</li> <li>As above</li> <li>As above</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>MR</li> <li>MR</li> <li>-NA-</li> </ul>
4	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors / Restt.</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>Required</li> </ul>	<ul style="list-style-type: none"> <li>As above</li> <li>Smoke venting provided</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>MR</li> </ul>
5	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI Marking</li> </ul>	<ul style="list-style-type: none"> <li>06 Nos</li> <li>ABC / CO2</li> <li>ISI marked</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>ABC type</li> <li>Provided</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>MR</li> </ul>
6	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor.</li> <li>• Length of hose-reel hose.</li> <li>• Nozzle Diameter</li> </ul>	<ul style="list-style-type: none"> <li>One near Restt.</li> <li>30m</li> <li>5mm</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>Provided</li> <li>Provided</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>MR</li> </ul>

*Handwritten signature*

7	<b>Automatic fire detection &amp; alarming system. (Provided &amp; Maintained by Building Mgmt.)</b>			
	• Type of detectors	Required	Smoke & Heat	MR
	• Location of Main Panel	Required	Mezzanine floor	MR
	• Location of Repeater Panel	Required	FCR at GF	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	All area	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	-NA-	As above	-NA-
10	<b>Automatic Sprinkler System</b>			
	Provided & Maintained by Building Mgmt.			
	• Basement LG Floor	Required	Provided	MR
	• Upper floors	-NA-	As above	-NA-
	• Sprinkler above false ceiling	-NA-	As above	-NA-
11	<b>Internal Hydrants.</b>			
	Provided & Maintained by Building Mgmt.			
	• Size of Riser/Down-comer	-NA-	As above	-NA-
	• Number of Hydrant per floor	One near Restt.	Provided	MR
	• Hose box.	One near Restt.	Provided	MR
12	<b>Yard Hydrants.</b>			
	Provided & Maintained by Building Mgmt.			
	• Total number of hydrants.	-NA-	As above	-NA-
	• Hose box.	-NA-	As above	-NA-
13	<b>Pumping arrangements.</b>			
	Common pumping arrangements for entire Bldg.			
	• <b>Ground Level</b>	Provided & Maintained by Building Mgmt.		
	➤ Discharge of main pump.	-NA-	2280 LPM	-NA-
	➤ Head of main pump.	-NA-	105m	-NA-
	➤ Number of main pumps.	-NA-	Two	-NA-
	➤ Jockey Pump output.	-NA-	2 x 180 LPM	-NA-
	➤ Jockey Pump head.	-NA-	105m	-NA-
	➤ Standby Pump output.	-NA-	2280 LPM	-NA-
	➤ Standby Pump head.	-NA-	105m	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	Provided	-NA-
	➤ Pump House Access	-NA-	Provided	-NA-
	• <b>Terrace Level</b>	Provided & Maintained by Building Mgmt.		
	➤ Discharge of pump.	450 LPM	900 LPM	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	<b>Captive water storage for Fire Fighting. (Provided &amp; Maintained by Building Mgmt.)</b>			
	• Underground tank capacity.	-NA-	1,50,000 Ltr	-NA-
	➤ Draw-off connection.	-NA-	Provided	-NA-
	➤ Fire Service Inlet.	-NA-	Provided	-NA-
	➤ Access to tank.	-NA-	Provided	-NA-
	• Overhead tank capacity.	10,000 Ltr	20,000 Ltr	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	Provided & Maintained by Building Mgmt.			
	• Pressurization of lift shaft.	-NA-	As above	-NA-
	• Pressurization of lift lobby.	-NA-	As above	-NA-
	• Communication in lift car.	-NA-	As above	-NA-
	• Fireman's switch.	-NA-	As above	-NA-
	• Lift signage.	-NA-	As above	-NA-
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	Provided & Maintained by Building Mgmt.			
	• Total area	-NA-	550 m <sup>2</sup>	-NA-
	• Location	-NA-	6 <sup>th</sup> floor	-NA-

SA

2

19	Fire Control Room.	Provided & Maintained by Building Mgmt.		
	• Detector System Panel.	-NA-	As above	-NA-
	• Flow Switch Panel.	-NA-	As above	-NA-
	• PA system Panel.	-NA-	As above	-NA-
	• Battery backup	-NA-	As above	-NA-
	• Building floor plan	-NA-	As above	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any:	-NA-	As above	N/A

The fire protection systems provided in the building/premises checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/EH/SZ/2021/176 dated 10/08/2021, renewal under rule 37 of Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Manoj*

Signature of the Inspecting Officer  
Name: Manoj Kumar Sharma  
Designation: DO (SD)

*Santosh Kumar*  
*26/04/24*

Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (S.J.)

CFO/HQ *30/4/2024*

Director *24/04/24* *FT PL*  
*ADJ SJ*

*F-T letter is put up for sig. pl*

Dir *1/05/24*

*1*  
*MSJ*  
*01/5*

*Unloaded*  
*01/5/24*  
*SJ*