



041

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/EH/2024/SZ/ 117

Dated: 01/05/2024

FIRE SAFETY CERTIFICATE

Certified that M/s **Kampai** (A unit of Tasteshop Pvt. Ltd) located at G-02, Ground Floor, Asset-11, Worldmark-1, Aerocity, IGI Airport, New Delhi-110037, comprised of Three Basements, Ground, Mezzanine + 06 upper floors but the restaurant running at Ground Floor only, owned/occupied by A unit of Tasteshop Pvt. Ltd, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/2021/SZ/207 dated 02/09/2021. The said restaurant was re-inspected by the officers concerned of this department on 25/04/2024 in the presence of Mr. Rakesh Pandey (Asst. Manager) of the restaurant and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said premise is fit for occupancy class "**Assembly Group D**" (Eating House) up to **31/03/2027** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/05/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

ok M

Copy to:-

1. The Joint Commissioner of Police, Licensing Branch, First Floor, Police Station Defence Colony, New Delhi-110049 (w.r.t. MHA ID No. 2024041405076 dated 15/04/2024)
2. Mr. Pranay Bahl M/s Kampai (A unit of Tasteshop Pvt. Ltd) at G-02, Ground Floor, Asset-11, Worldmark-1, Aerocity, IGI Airport, New Delhi-110037

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its

N-12

INSPECTION REPORT			
1	Name & Address of the Building	M/s Kampai (A unit of Tasteshop Pvt. Ltd) at G-02, Ground Floor, Asset-11, Worldmark-1, Aerocity, IGI Airport, New Delhi-110037	
2	Type of Occupancy	Assembly 'Group-D' (Restt. at Ground Floor)	
3	Building comprised of	03 Basements, Mezzanine, Ground + 06 floors.	
4	Type of Case	Renewal	
5	Details of Previous NOC	F.6/DFS/MS/EH/2021/SZ/207 dated 02/09/2021	
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2017/Hotel/368 dated 21/02/2017	
7	Date of Inspection	25/04/2024	
8	Name of the Inspecting Officers	Manoj Kumar Sharma (DO/SD), Santosh Kumar (ADO/SJ)	
9	Name & Designation of Officers from the building side	Mr. Rakesh Pandey (Asst. Manager)	
10	Year of construction	2014	
11	Applicant letter No.	MHA ID No. 2024041405076 dated 15/04/2024	
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements	Remarks MR/NMR
1	Access to Building	FSC No F.6/DFS/MS/Mixed/2024/SZ/HTL/12 dated 12/03/2024	
	• Road width	Restt located	As above MR
	• Gate width	within	As above N/A
	• Width of internal road	Worldmark-I	As above N/A
2	Number, width, type & arrangement of exits		
	a. Number of Staircase	Provided & Maintained by Building Mgmt.	
	• Upper floors	-NA-	As above -NA-
	• Basement floor	-NA-	As above -NA-
	b. Width of Staircase	Provided & Maintained by Building Mgmt.	
	• Upper floors	N/A	As above -NA-
	• Basement floor	N/A	As above -NA-
	c. Protection of exits	Provided & Maintained by Building Mgmt.	
	• Fire check door	-NA-	As above -NA-
	• Pressurization	-NA-	As above -NA-
	d. No. of continuous staircase to terrace	Required	As above MR
	e. Width of corridor	-NA-	-NA- -NA-
	f. Door size	2m / 1.35m	2m, 1.40m & 1.06m MR
3	Compartmentation.	Provided & Maintained by Building Mgmt.	
	• Fire check door.	Required	As above MR
	• Sealing of electrical shafts.	Required	As above MR
	• Fire rating of shaft door.	Required	As above MR
	• Water curtain	Required	As above MR
	• Fire dampers.	-NA-	As above -NA-
4	Smoke Management system.	Provided & Maintained by Building Mgmt.	
	• Basement	-NA-	As above -NA-
	• Upper floors / Restt.	Required	Smoke venting provided MR
5	Fire Extinguishers.		
	• Total numbers	06 Nos	Provided MR
	• Types	ABC / CO2	ABC type MR
	• ISI Marking	ISI marked	Provided MR
6	First Aid Hose Reels.	Provided & Maintained by Building Mgmt.	
	• Total numbers on each floor.	One near Restt.	Provided MR
	• Length of hose-reel hose.	30m	Provided MR
	• Nozzle Diameter	5mm	Provided MR

7	Automatic fire detection & alarming system. (Provided & Maintained by Building Mgmt.)			
	• Type of detectors	-NA-	Smoke & Heat	-NA-
	• Location of Main Panel	-NA-	Mezzanine floor	-NA-
	• Location of Repeater Panel	-NA-	FCR at GF	-NA-
	• Alternate source of power	-NA-	Provided	-NA-
	• Hooter's location	-NA-	All area	-NA-
8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	As above	-NA-
10	Automatic Sprinkler System			Provided & Maintained by Building Mgmt.
	• Basement	-NA-	As above	-NA-
	• Upper floors / Restt Area	-NA-	As above	-NA-
	• Sprinkler above false ceiling	-NA-	As above	-NA-
11	Internal Hydrants.			Provided & Maintained by Building Mgmt.
	• Size of Riser/Down-comer	-NA-	As above	-NA-
	• Number of Hydrant per floor	-NA-	As above	-NA-
	• Hose box.	-NA-	As above	-NA-
12	Yard Hydrants.			Provided & Maintained by Building Mgmt.
	• Total number of hydrants.	-NA-	As above	-NA-
	• Hose box.	-NA-	As above	-NA-
13	Pumping arrangements.			Common pumping arrangements for entire complex
	• Ground Level	Provided & Maintained by Building Mgmt.		
	➤ Discharge of main pump.	-NA-	2280 LPM	-NA-
	➤ Head of main pump.	-NA-	105m	-NA-
	➤ Number of main pumps.	-NA-	Two	-NA-
	➤ Jockey Pump output.	-NA-	2 x 180 LPM	-NA-
	➤ Jockey Pump head.	-NA-	105m	-NA-
	➤ Standby Pump output.	-NA-	2280 LPM	-NA-
	➤ Standby Pump head.	-NA-	105m	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	Provided	-NA-
	➤ Pump House Access	-NA-	Provided	-NA-
	• Terrace Level	Provided & Maintained by Building Mgmt.		
	➤ Discharge of pump.	450 LPM	900 LPM	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for Fire Fighting. (Provided & Maintained by Building Mgmt.)			
	• Underground tank capacity.	-NA-	1,50,000 Ltr	-NA-
	➤ Draw-off connection.	-NA-	Provided	-NA-
	➤ Fire Service Inlet.	-NA-	Provided	-NA-
	➤ Access to tank.	-NA-	Provided	-NA-
	• Overhead tank capacity.	10,000 Ltr	20,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			Provided & Maintained by Building Mgmt.
	• Pressurization of lift shaft.	-NA-	As above	-NA-
	• Pressurization of lift lobby.	-NA-	As above	-NA-
	• Communication in lift car.	-NA-	As above	-NA-
	• Fireman's switch.	-NA-	As above	-NA-
	• Lift signage.	-NA-	As above	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			Provided & Maintained by Building Mgmt.
	• Total area	-NA-	550 m ²	-NA-
	• Location	-NA-	6 th floor	-NA-

SE


✓


19	Fire Control Room.	Provided & Maintained by Building Mgmt.		
	• Detector System Panel.	-NA-	As above	-NA-
	• Flow Switch Panel.	-NA-	As above	-NA-
	• PA system Panel.	-NA-	As above	-NA-
	• Battery backup	-NA-	As above	-NA-
	• Building floor plan	-NA-	As above	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any:	-NA-	As above	N/A



The fire protection systems provided in the building/premises checked, tested at random and found functional at the time of inspection.


Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/ EH/2021/SZ/207 dated 02/09/2021, renewal under rule 37 of Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.




 Signature of the Inspecting Officer
 Name: Manoj Kumar Sharma
 Designation: DO (SD)


 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (S.J.)

~~CFO (HQ)  30/4/2024~~
~~Director  11/05/24~~

~~DC/SD  01/5~~
~~AD/SD~~

F.T. letter is put up for sig. pl

~~Dir. DFS  11/5/24~~

 01/5/24

Uploaded
 01/5/24 