



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/ 2024/ 296

Dated / 0 105 / 2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Prayas Juvenile Aid Centre located at Jahangirpuri, Delhi-110033 comprised of 02 Blocks Interconnected, Ground & 03 upper floors owned/ occupied by M/s Prayas Juvenile Aid Centre have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 03.05.2024 in the presence of Sh. Bhupesh (Program Officer) and that the building/ premise is fit for occupancy Class "Mixed occupancy (Educational & Residential) with effect from 10/05/2024 for a period of three year, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..10/05/2024.... at New Delhi by

(Anil Garg)
Director

Ph-011-23414000

of c by

Copy to:-

1. Executive Director, M/s Prayas Juvenile Aid Centre located at Jahangirpuri, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Prayas Juvenile Aid Centre at Jahangirpuri, Delhi-110033.
2. Composition of building : 02 Blocks Interconnected, Ground & 03 upper floors only
3. Type of Occupancy : Mixed occupancy (Educational + Residential)
4. Type of Case : New Case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : F6/DFS/MS/BP/95/1426 dated 15.09.1995
F6/DFS/MS/BP/97/508 dated 06.05.1997
7. Date of inspection : 03.05.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers : Mr. Bhupesh (Program Officer)
10. Year of Construction : 1995
11. Applicant's letter No. : Letter No. Nil Dated: 16.04.2024

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL-1983 Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	08m	MR
	• Gate width	05m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos	02nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	2nos	2nos	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural ventilated	MR
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types IS marking 	24nos	Provided	
		ISI marked	yes	
		Required	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02nos each floor	Provided	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	No basement	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm	Provided	MR
		02at each Floor	Provided	MR
		02 at each Floor	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	900 LPM	Provided	MR
		40m	Provided	MR
		01	Provided	MR
		NA	NA	NA
		NA	NA	NA
		900 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	50,000 LTR	Provided	MR
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	12,500 LTR	15,000 LTR	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of satisfactory compliance of the minimum standards on fire prevention and fire safety required under the rules and fire safety guidelines issued vide letter of even no.F6/DFS/MS/BP/97/508 dated 06.05.1997, it is recommended to grant Fire Safety Certificate.

Dy. Chief Fire Officer (WZ)

Signature of the Inspecting Officer
 Name :-C.L. Meena
 Designation:- Asst. Div. Officer/RN

There is no pending file before receipt of this file.

8/5/2024
 7/5/2024

Director
 8/5/2024

Asst. Div. Officer

7/5/2024