

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001
 No.F6/DFS/MS/EH/NDZ/2024/ 125 Dated : 03/05/2024

FIRE SAFETY CERTIFICATE

Certified that the M/S Haldiram Product Pvt. Ltd located at 70, Janpath Connaught Place, New Delhi comprises of Ground, mezzanine & 02 upper floors, and Restaurant at Ground only. The FSC was earlier granted FSC by this department vide letter No.F6/DFS/MS/EH/NDZ/2021/77 dated 30/03/21 for the ground floor only and storage at mezzanine. Now, the premises was re-inspected by the officers concerned of this department on 24/04/24 in the presence of Manager and found that the restaurant running at ground and mezzanine closed as per undertaking dated 25.04.24, has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the said restaurant is fit for occupancy class **Assembly Building Group D, Restaurant at ground floor only** and valid up to 31.03.2027 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ...03/05/2024...at New Delhi by.


 (Atul Garg)
 DIRECTOR
 Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Dy. Commissioner of Police (Lic.), Ist floor, PS Defence Colony, New Delhi, ID No. 2024041304956 dated 13.04.2024.
3. The Manager, M/s Haldiram at 70, Janpath Connaught Place, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid only for restaurant at ground floor.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority. Mezzanine floor shall be used only for storage purpose no seating shall be allowed.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
10. Any flammable material for interior decoration is strictly prohibited.

19
INSPECTION REPORT

1. Name & address of the building Haldiram Product Pvt. Ltd. located at 70, Janpath Connaught Place, New Delhi
2. Type of occupancy:- Assembly Building Group-D, Ground + Mez. and 02 upper floors and Restaurant is running on Ground floor only .
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/NDZ/2021/77 dated 30/03/21.
5. Fire safety directives No.- N/A
6. Date of inspection:- 24.04.2024
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD) & Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Manager
9. Year of construction:- 1960
10. Applicant's letter No:- online id no. 2024041304956 dated 13.04.2024.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr	06 mtr. ✓	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors (mezzanine floor closed & not in use)	N/A	02 nos ✓	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors (mezzanine)	N/A	02 of 1.5m & .50 m ✓	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 mtr	1.5 mtr ✓	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR

5.	Fire Extinguishers		06 Nos.	06 Nos.	MR
	1) Total numbers		ABC & CO2	ABC & CO2	MR
	2) Types		Required	Provided	MR
	3) ISI marking				
6.	First-Aid Hose Reel				MR
	1) Total number of each floor		01	01	MR
	2) Length of hose reel hose		30 mtr.	30 mtr.	MR
	3) Nozzle diameter		05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System				
	1) Type of detectors		N/A	N/A	N/A
	2) Location of main panel		N/A	N/A	N/A
	3) Location of repeater panel		N/A	N/A	N/A
	4) Alternate source of power		N/A	N/A	N/A
	5) Hooter's Location		N/A	N/A	N/A
8.	MOEFA		Required	Provided	MR
9.	Public Address System		Required	Provided	MR
10.	Automatic Sprinkler System				
	1) Basement		N/A	N/A	N/A
	2) Upper floors		N/A	Provided	N/A
	3) Sprinkler above false ceiling		N/A	N/A	N/A
11.	Internal Hydrants				
	1) Size of riser/down-comer		100mm	100mm	MR
	2) Number of hydrants per floor		01	01	MR
	3) Hose box		01	01	MR
12.	Yard Hydrants				
	1) Total number of hydrants		N/A	N/A	N/A
	2) Hose box		N/A	N/A	N/A
13.	Pumping Arrangement				
	1) Ground level		N/A	N/A	N/A
	a) Discharge of main pump		N/A	N/A	N/A
	b) Head of main pump		N/A	N/A	N/A
	c) Number of main pump		N/A	N/A	N/A
	d) Jockey pump out put		N/A	N/A	N/A
	e) Jockey pump head		N/A	N/A	N/A
	f) Stand by pump output		N/A	N/A	N/A
	g) Stand by pump head		N/A	N/A	N/A
	h) Auto starting/Manual stopping		N/A	N/A	N/A
	2) Terrace level				
	a) Discharge of pump		450 LPM	Provided	MR
	b) Head of pump		30 mtr.	Provided	MR
	c) Power supply		Required	Provided	MR
d) Auto starting of pump		Required	Provided	MR	



2/11

14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 lit.	20,000 lit. ✓	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the said building were randomly tested, checked and found functional at the time of inspection. An undertaking dated 25.04.2024 regarding not to use mezzanine floor for any purpose has been submitted by applicant and same is placed on file.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2021/77 dated 30/03/21, under rule 35 of the Delhi Fire Service rules 2010. Accordingly, reply letter is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

[Signature] 25/4/24

Name: - Sh. Rajinder Attwal
Designation: - DO (CD)

Signature of the Inspecting Officer

[Signature] 25/4/24

Name: - Ravinder Singh
Designation: - ADO (CC)

[Signature]

[Signature] 26/04/24

C.I.F.O. *[Signature]* 30/4/2024

[Signature] 05/24

[Signature]