

C-86

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No.F.6/DFS/MS/EH/2024/SZ/ 123

Dated: 03/05/2024


**FIRE SAFETY CERTIFICATE**

Certified that the M/s Love Liquor Bar, Shop no.-29, running at ground floor of a building comprised of Basement, ground plus four upper floors, Plot No. 7A, District Centre, Janakpuri, New Delhi-110058, owned/occupied by M/s Love Liquor Bar, was issued FSC by this department vide letter no. F.6/DFS/MS/EH/2021/SZ/107 dated 22.04.2021 (for name of Barshala). The restaurant building was re-inspected by the officer concerned of this department on 25.04.2024 in the presence of Sh. Sunil Sharma & Sh. Pankaj Singh and found that the restaurant building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (Ground Floor Only) is fit for occupancy class Group-D "Assembly Building" w.e.f. 03/05/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....03/05/2024..... at New Delhi by

  
(Atul Garg)  
Director

Delhi Fire Service



Online application ID 2024041204839 dated 01.04.2024.

**Following fire safety directives must be adhered to:-**

- This NOC is valid only for ground floor.
- The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- All the means of escape shall be kept free of all the type of obstruction all the time.
- All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
- All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
- This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/22

**INSPECTION REPORT**

1. Name & address of the building : M/s Love Liquor Bar at GF, Plot No. C-62, Janak Complex, Community Centre, Janakpuri, New Delhi- 110058.
2. Building comprised of : B, G+4 Upper Floors but restaurant running at ground floor only
3. Type of Occupancy : Group D (Assembly)
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/EH/2021/SZ/107 dated 22.04.2021 (for name of Barshala)
6. Fire Safety directives letter No : N/A
7. Date of inspection : 25.04.2024
8. Name of Inspecting Officers : A.D.O. R.K.Yadav
9. Name and designation of officers  
From the building side : Sh. Sunil Sharma & Sh. Pankaj Singh
10. Year of Construction : Before 2009
11. Applicant's letter No. : Online application ID 2024041204839 dated 01.04.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	09 mtrs. 4.5 mtrs. N/A	Provided Directly accessible from road N/A	M/R M/R N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits (Restaurant is running at GF only)</b>			
	a. Number of staircases			
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.50 m	Opening in hall	M/R
	f. Door Size	2.0 & 1.50 m	2.0 & 1.50 m	MR
3.	<b>Compartmentation</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	• Basements	N/A	N/A	N/A
	• Ground floor	Required	Provided	M/R
5.	<b>Fire Extinguishers</b>			
	• Total numbers in restaurant	06 no.'s ABC/CO <sub>2</sub> ISI marked	Provided	M/R
	• Types		Provided	M/R
	• IS marking		Provided	M/R
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers for restaurant	One 30 mtrs 5 mm	Provided	MR
	• Length of hose reel hose		Provided	MR
	• Nozzle diameter		Provided	MR

N/23

7.	<b>Automatic fire detection and alarming system in restaurant</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Type of detectors Smoke/Heat</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
8.	<b>MOEFA with talk back system</b>	Required	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor at restaurant</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>	100 mm	Provided	MR
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants for restaurant</li> <li>Hose Box</li> </ul>	One	Provided	MR
		One	Provided	MR
12.	<b>Yard Hydrants</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> </ul> </li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Water curtain Pump</li> <li>Auto Starting/Manual Stopping</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump House Access</li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		450 LPM	Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity for entire bldg. <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
		20000 ltrs	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	<b>Standby power supply</b>	Required	Provided	M/R
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A

N/24

Fire Control Room			
• Detector System Panel	N/A	N/A	N/A
• Flow Switch Panel	N/A	N/A	N/A
• PA System Panel	N/A	N/A	N/A
• Battery backup	N/A	N/A	N/A
• Building Floor Plans	N/A	N/A	N/A
20. Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/2021/SZ/107 dated 22.04.2021 renewal under rule 37 of the Delhi Fire Service rules 2010, is recommended.

Note: - M/s Love Liquor Bar, running at Ground floor only with separate entry/exit. Building is comprised of basement, ground plus four upper floors.

*R. K. Yadav*  
 Signature of Inspecting Officer  
 Name: - R. K. Yadav  
 Designation: - ADO (JKP)

D.O. (SW)  
*ah*  
 29/4/24

CFO (S2)  
*High*  
 29/4/2024

Director  
*[Signature]*  
 29/4/24

*ADP/SW*

F T letter a put up for signature please

DIRECTOR  
*[Signature]*

*ADP/SW*

*ADP/SW*

*[Signature]*  
 29/4/24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/SZ/2024/ 178

Dated: 09/05/2024

To

The Joint Commissioner of Police (Licensing),  
Licensing Unit, Delhi Police,  
1<sup>st</sup> Floor, P. S. Defence Colony, New Delhi.

Corrigendum letter

Sir,

With reference to party letter No. nil, dated 07.05.2024, received in this department vide outdoor dairy No. 1467 on dated 07.05.2024, regarding the correction in recipient of Fire Safety Certificate issued by this department in the name & style of M/s Love Liquor Bar, located at Shop No. C-62, Ground Floor, Community Centre, Janak Complex, Janakpuri, New Delhi-110018, vide this office letter No. F.6/DFS/MS/EH/2024/SZ/123, dated 03-05-2024. The address of the Eating House in the Fire Safety Certificate was mentioned as Shop No. 29, Ground Floor, Plot No. 7A, District Centre, Janakpuri, New Delhi-110058 and the same should be read as **Shop No. C-62, Ground Floor, Community Centre, Janak Complex, Janakpuri, New Delhi-110018**. Rest all contents in Fire Safety Certificate shall remain unchanged. The FSC stands modified as above.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

Copy to: -

Sh. Pankaj Kumar Singh, Proprietor for M/s Love Liquor Bar,  
Shop No. C-62, Ground Floor, Community Centre,  
Janak Complex, Janakpuri, New Delhi-110018