

C 76

FORM 'H'
 FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
 HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
 NEW DELHI

No. F6/DFS/MS/2024/GH/137

Dated: 13/05/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Shhaurya Guest House, located at Plot no-16, Pocket-B, Sector -13 Dwarka New Delhi, running at G.F =Reception, open hall, 1st & 2nd floor= 7 rooms each floor & 3rd floor = 6 rooms (Total 20 rooms) in a building comprised of Basement + Ground + 3 Upper Floors was issued FSC vide Letter No F6/DFS/MS/SWZ/2021/GH/485 dated 28/10/2021. The premises was re inspected by the officer concerned of this department on 02/05/2024 in the presence of Dr. D. N. Mishra (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Lodging or rooming building" Group A-1 {At G.F =Reception, open hall, 1st & 2nd floor= 7 rooms each floor & 3rd floor = 6 rooms Total 20 rooms} with effect from 13/05/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/05/2024... at New Delhi by.


 (Atul Gang)
 Director
 Delhi Fire Service
13/05/24

Copy to:

1. The Joint. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Manager, M/s Shhaurya Guest House, plot no-16, Pocket-B, Sector -13 Dwarka New Delhi.

Following fire safety directives must be adhered to:-

1. **The Exits /passage to stair shall be kept free from any obstruction/ lock and key.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement strictly shall be kept vacant as seen during inspection.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: M/s Shhaurya Guest House, located at Plot no-16, Pocket-B, Sector-13 Dwarka New Delhi.
2. Type of Occupancy: Lodging or rooming;- Lodging or rooming "A-1"
3. Type of Case : Renewal Running at 1st, 2nd & 3rd floor building comprise of (Basement + Ground + 3 Upper Floor)
4. Details of previous NOC : F6/DFS/MS/SWZ/2021/GH/485 dated 28/10/2021
5. Fire Safety directives Letter No. : Old Case
6. Date of inspection : 02/05/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Dr. D. N. Mishra (Manager)
9. Year of Construction : 2014
10. Applicant's letter No. : 2024032603584 dated 18/04/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/6, N/7 & N/8	Provided at site	Remarks MR/NMR
1.	Access of building	06 mtr	12 mtr	MR
	• Road width	NA	NA	NA
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	2 Nos	2Nos	MR
	• Upper floors	2 Nos	2 Nos	MR
	• Basements			
	b. Width of staircases	1.5m & 1.25m	Provided	MR
	• Upper floors	1.5m & 1.25m	1.5m & 1.2m	MR old case
	• Basements			
	c. Protection of exits	Required	Provided	MR
	• Fire check door	NA	NA	NA
	• Pressurization	01	Provided	MR
	d. No of continuous staircase to terrace	1.25 mtr	1.25 mtr	MR
	e. Width Of Corridor	1m	1m	MR
	f. Door Size			
3.	Compartmentation	Required	Provided	MR
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System	30 a/c per hour	Provided	MR
	• Basements	12 a/c per hour	Provided	MR
	• Upper floors			

(Handwritten Signature)

N/99

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10Nos. ABC Required	12 Nos CO ₂ & ABC Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 mtr 5 MM	Provided 30 mtr 5 MM	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	CO Detectors Required	Provided Provided	MR MR NA MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm 01 no Required	Provided 01 no Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA 900 LPM,180 lpm 35 mtrs Required Required	NA NA NA NA NA NA NA NA NA NA Provided 35mtrs DG set 125 KVA Provided	NA NA NA NA NA NA NA NA NA NA MR MR MR MR

1/10

14.	Captive water Storage for fire fighting:		
	• Under ground tank capacity	NA	NA
	➤ Draw off connection	NA	NA
	➤ Fire service inlet	NA	NA
	➤ Access to tank	NA	NA
	• Overhead Tank capacity	10000 ltrs	Provided
15.	Exit Signage	Required	Provided
16.	Provision of Lifts		
	➤ Pressurization of Lift Shaft	NA	NA
	➤ Pressurization of lift lobby	NA	NA
	➤ Communication in lift Car	Required	Provided
	➤ Fireman's Grounding Switch	Required	Provided
	➤ Lift Signage	Required	Provided
17.	Standby power supply	Required	Provided
18.	Refuge Area		
	➤ Total area	NA	NA
	➤ Location	NA	NA
19.	Fire control room		
	➤ Detector system panel	NA	NA
	➤ Flow Switch Panel	NA	NA
	➤ PA System Panel	NA	NA
	➤ Battery backup	NA	NA
	➤ Building Floor Plans	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Co2 fire extinguisher provided near electric panel
			MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/SWZ/2021/GH/485 dated 28/10/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

UD
AT 5/24

Signature of the Inspecting Officer
Name: Udai vir Singh
Designation : ADO (DWK)

DO/SW
ADP

CRD (SW)
8/5/2024
Director
M/S

ADP