

c/46

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2024/SZ/ 424

Dated: 15/05/2024

FIRE SAFETY CERTIFICATE

Certified that the **Brilliance School** located at RZ-9/10, X-Block, New Roshanpura, Najafgarh, New Delhi-110043. The school building comprised of ground plus three upper floors but school running at ground, first and second floor only, third floor (02 rooms) is not in use. Owned/occupied by Brilliance School have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010, and verified by the officer concerned of this department on 26.04.2024 in the presence of Sh. Ajit Kalkal (Chairman) and found that the building/ premises is fit for occupancy class B 'Educational Building' (for ground, 1st & 2nd floor only) with effect from 15/05/2024 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 15/05/2024 at New Delhi by.


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Chairman, Brilliance School located at RZ-9/10, X-Block, New Roshanpura, Najafgarh, New Delhi-110043.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

- N/1
1. Name & address of the building : Brilliance School, RZ- 9/10, X-Block, New Roshanpura, Najafgarh, New Delhi-110043
 2. Building comprised of : ground plus three upper floors but school running at ground, first & second floor only.
 3. Type of Occupancy : Educational
 4. Type of Case : New Case
 5. Details of Previous NOC : F.6/DFS/MS/School/2019/SZ/2043 dated 24/10/2019
 6. Fire Safety directives letter No : N/A
 7. Date of inspection : 26.04.2024
 8. Name of Inspecting Officer : A.D.O. R.K.Yadav
 9. Name and designation of officers
From the building side : Sh. Ajit Kalkal (Chairman)
 10. Year of Construction : 2015-16
 11. Applicant's letter No. : Nil dated 08.04.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Dt. of edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	6.0 mtrs.	Provided	M/R
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	N/A N/A	Directly accessible from road N/A	N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02 No's	02 No's	M/R
	<ul style="list-style-type: none"> • Upper Floors • Basement 	N/A	N/A	N/A
	b. Width of staircases	1.5 & 1.0 m	1.60 m & 1.15 m	M/R
	<ul style="list-style-type: none"> • Upper Floor • Basements 	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	One	MR
	e. Width of Corridor	1.50 m	Provided	M/R
	f. Class room Door Size	1.0 m	1.20 m	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	12 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	MR MR MR

Travel distance is meeting with single staircase of 1.5 Meter

N/2

16. Pro

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM 40 m Required Required	Provided Provided Provided Provided	MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 10,000 ltrs	N/A N/A N/A N/A Provided Provided	N/A N/A N/A N/A MR MR
15.	Exit Signage.	Required	Provided	MR

Handwritten marks at the bottom of the page.

16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Note :- As per undertaking (placed at C-43) school building comprised of ground plus three upper floors, but school running at ground, first & second floor only and third floor (02 rooms) is not in use.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under Rule 35 of the Delhi Fire Service Rules 2010, it's recommended to grant Fire Safety Certificate.

[Handwritten Signature]
 Signature of Inspecting Officer
 Name:- R.K. Yadav
 Designation:- ADO (JKP)

D.O (South West)
[Handwritten Signature]
 2/5/24
 CFO (S2)
 Director
 2/5/2024
 3/5/24

[Handwritten Signature]