

G-70

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/2024/ 142

Dated : 14/05/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Hotel Fortuner, 943, Gali no. 3 & 4 Naiwala, Faiz Road, Karol Bagh, New - Delhi- 110005, comprised of Basement, Ground + 03 upper floors, Basement (Storage), Ground floor (04 guest rooms + Reception), 1st floor to 3rd floor (07 guest rooms at each floor) total 25 rooms upto third floor and submitted affidavit by owner dated 26/11/2024 not to use any floor above third floor, was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/SZ/2021/300 dated 11/08/21. Now, the premises was re-inspected by the officer concerned of this department on 01/05/24 in the presence of Mr. Tozo and found that the said guest house building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, Sub Division-A-1 as Basement (Storage), Ground floor (04 guest rooms + Reception), 1st floor to 3rd floor (07 guest rooms at each floor) total 25 rooms up to third floor, and valid up to 31.03.2027 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued... 14/05/2024... at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. ID no. 2024041605309 dated 16.04.24.
3. The Manager, Hotel Fortuner, 943, Gali no. 3 & 4 Naiwala, Faiz Road, Karol Bagh, New - Delhi- 110005.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

M/2

INSPECTION REPORT

1. Name & address of the building **M/S Hotel Fortuner, 943, Gali no. 3 & 4 Naiwala, Faiz Road, Karol Bagh, New - Delhi- 110005.**
2. Type of occupancy:- **Residential, Sub Division-A-1
B + Ground + 03 Upper floors (total 25 guest rooms)
Basement (Storage), Ground floor (04 guest rooms + Reception), 1st floor to 3rd floor (07 guest rooms at each floor) total 25 rooms upto third floor**
3. Type of case:- **Renewal**
4. Details of previous FSC:- **F6/DFS/MS/GH/SZ/2021/300 dated 11/08/21.**
5. Fire safety directives No.- **N/A**
6. Date of inspection:- **01/05/24**
7. Name of the inspecting officer:- **Sh. Ravinder Singh (ADO/CC)**
8. Name & designation of officer
From the building side:- **Mr. Tozo**
9. Year of construction:- **2009-10**
10. Applicant's letter No:- **Online Id no.2024041605309 dated 16.04.24.**

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr	Provided.	MR
	2) Gate width	-----	Directly accessible ✓	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos. ✓	MR
	2. Basements	01 Nos.	01 Nos.	MR being old case
	B. Width of staircase			
	1. Upper floors	old case.	1.26 mtr. ✓	MR
	2. Basements	1.5 mtr.	2.40 mtr. ✓	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	N/A
	E. Width of corridor	01mtr	1.47mtr ✓	N/A
	F. Door size	old case	0.86 mtr. ✓	MR being old case
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Natural/exhaust	MR

M/22

5.	Fire Extinguishers			
	1) Total numbers	16 Nos.	Provided	MR
	2) Types	ABC & CO2, WCO2	Provided	MR
	3) ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO type	Required	Provided	MR
	2) Location of main panel	Required	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	Provided	MR (area is less than 200sq. mtr.)
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A

N/23

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10000 ltr.	10000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, the FSC issued vide letter no. No. No. F6/DFS/MS/GH/SZ/2021/300 dated 11/08/21, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval up to third floor.

Signature of the Inspecting Officer



Name: - Ravinder Singh
Designation: - ADO (CC)

D9/9
7/5/24

Dy. C.O. (C/O)

Ravinder Singh
6/5/24

C.F.O. [Signature]
Director [Signature]
9/5/2024
[Signature]

[Signature]