



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**



No F 6 / DFS / MS / 2024 / WZ / 306

Dated: 16/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Aggarwal Metro Heights** located at **Plot No. E-5, Netaji Subhash Place, Pitampura, Delhi- 110034** comprised of **Basement, Ground plus 15 upper floors** was issued FSC by this department vide letter No F6/DFS/MS/WZ/2021/192 dated 30.03.2021. The premise was re-inspected by the officer concerned of this department on 10.05.2024 in the presence of **Sh. Ajay Chauhan (G.M)** and found that that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy class "Mercantile & Business Building" Group F & Group E with effect from 16/05/2024 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/05/2024 at New Delhi, by

  
( Atul Garg )  
Director  
Delhi Fire Service

Copy to: -

1. Sh. Sunil Kumar Jain, (Vice President), G-3, Aggarwal Corporate Tower, Plot No. 23, District Centre, Rajendra Place, New Delhi- 110008.
2. The Dy. Director (Bld.), Delhi Development Authority, Vikas Sadan, INA, Delhi.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
9. The Basement shall be used as per BBL.

**INSPECTION REPORT**

1. Name & address of the building : Aggarwal Metro Heights located at Plot No. E-5, Netaji Subhash Place, Pitampura, Delhi- 110034.
2. Type of Occupancy : Mixed (Mercantile & Business)
3. Building Comprised of : Basement + Ground + 15 Upper Floors.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/WZ/2021/192 Dated 30/03/2021
6. Fire Safety directives letter No : F6/DFS/MS/BP/2006/400 Dated 28/06/2017
7. Date of inspection : 10/05/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers  
From the building side : Sh. Ajay Chauhan (G.M.)
10. Year of Construction : 2008 as per N-8
11. Applicant's letter No. : UBL/AS/AMH/DFS/2K24/082 dated 03/05/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/ NBC Requirements/ Letter dated 30.03.2021	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	60 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	As per controlled drawing	MR
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floor	1.25 m & 1.5 m	1.22 m & 1.17 m	MR(old case)
	• Basements	1.25 m & 1.5 m	1.28 m & 1.34 m	MR(old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	Required	Provided	MR
4.	<b>Smoke Management System</b>			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	55Nos.	70 Nos.	MR
	• Types	ABC,Co2 & WCo2	Provided	MR
	• IS marking	Required	Provided	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	6.5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	Smoke/ Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR

	• Hooters' Location	Appropriate location	Provided near staircase	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	Required	Provided	MR
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	03	Provided	MR
	• Hose Box	Required	Provided	MR
13.	<b>Pumping Arrangements</b>			
	Ground Level			
	➤ Discharge of main Pump	2850 lpm	Provided	MR
	➤ Head of Main pump	110 m	Provided	MR
	➤ Number of main pumps	2	Provided	MR
	➤ Jockey Pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	110 m	Provided	MR
	➤ Standby Pump out put	2850 lpm	Provided	MR
	➤ Standby Pump Head	110 m	Provided	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	110 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	2,00,000 ltrs	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	NR	NR	MR
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	➤ Total Area	Old case	Old case	MR
	➤ Location	5 <sup>th</sup> , 7 <sup>th</sup> , 10 <sup>th</sup> & 12 <sup>th</sup> floor	Provided	MR
19.	<b>Fire Control Room</b>			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR

N-45

	PA System Panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risks, if any:	CO2 flooding system for LT & HT Panels	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter number F6/DFS/MS/WZ/2024/159 dated 28/03/2024.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to renew the fire safety certificate issued vide letter number F6/DFS/MS/WZ/2021/192 dated 30/03/2024 under rule 37 of the Delhi Fire Service Rules, 2010.

*ADO (B/W)*  
13/5/24

Signature of Inspecting Officer  
Name : Rajeev Kumar Sinha  
Designation : ADO/B.W.

*Dy. Commr*

*[Signature]*  
14/5

FOI 9/6/2024  
dated 14/05/24

*CF*  
*[Signature]*  
14/5/2024

*Director*  
*[Signature]*  
15/05/24

*ADO/B/W*

*Mr. G-T letter in Nuptop for sign place*  
*[Signature]*  
16/5/24

*Director (Dts)*  
*[Signature]*  
16/5/24  
*m*