



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/FH/2024/SZ/ 321

Dated: 22/05/2024

FIRE SAFETY CERTIFICATE

Certified that M/s **Ambria Farm House** Unit of Get Your Venue Events Pvt. Limited, F-20, Pushpanjali, Dwarka Link Road, New Delhi-110037, comprised of Basement, Ground plus one upper floor only, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/2021/201 dated 01/04/2021. The premise was re-inspected by the officers concerned of this department on 10/05/2024 in the presence of Mr. Jeeta Ram (Liaison Manager) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Assembly Group D" (Farm House) with effect from the date of issuance for a period up to **31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/05/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of Police, Licensing Unit, 1st Floor, Police Station Defence Colony, New Delhi-110049 (w.r.t. online MHA ID No. 2024042305937 dated 24/04/2024)
2. Authorized Signatory M/s Ambria Farm House Unit of Get Your Venue Events Pvt. Limited, F-20, Pushpanjali, Dwarka Link Road, New Delhi-110037

Conditions for the validity of Fire Safety Certificate:

1. **This NOC is not valid for temporary structure if erected/altered.**
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

N-17

INSPECTION REPORT

1.	Name & address of the building	M/s Ambria Farm House Unit of Get Your Venue Events Pvt. Limited, F-20, Pushpanjali, Dwarka Link Road, New Delhi-110037		
2.	Type of Occupancy	Assembly "Group D" (Farm House)		
3.	Building Comprised of	Basement, Ground plus one upper floor & Open Farm House.		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/SZ/2021/201 dated 01/04/2021		
6.	Fire Safety Directives Letter No.	F6/DFS/MS/2009/2218 dated 23/07/2009		
7.	Date of inspection	10/05/2024		
8.	Name of Inspecting Officer	Manoj Kumar Sharma (DO/SD) Santosh Kumar (ADO/SJ)		
9.	Name and designation of Officer from building side	Mr. Jeeta Ram (Liaison Manager)		
10.	Year of Construction	2009		
11.	Applicant letter No.	MHA ID No. 2024042305937 dated 24/04/2024		
S. No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	25m	MR
	• Gate width	5m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Required	03 Nos	MR
	• Basements	Required	02 Nos	MR
	b. Width of staircases			
	• Upper floors	Required	2 x 0.80m & 0.90m	MR (old case)
	• Basements	Required	2 x 0.90m	MR (old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	One	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	08 Nos	12 Nos	MR
	• Types	ABC/CO ₂	ABC, CO ₂ & W.CO ₂	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

SF

~

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	Required	03 Nos	MR
	• Hose Box	Required	03 Nos	MR
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	180 & 900 LPM	Provided	MR
	➤ Head of the pump	40m (each)	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection system provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/SZ/2021/201 dated 01/04/2021, renewal under rule 37 of DFS Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Handwritten Signature]

Signature of the Inspecting Officer
Name: Manoj Kumar Sharma
Designation: DO (SD)

[Handwritten Signature]
13.05.24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

CFO (HOs)

[Handwritten Signature]
16/5/2024
Director *[Handwritten Signature]*
16/5/24

[Handwritten Signature]

Sir,

FT letter is put up for your sig. pl

[Handwritten Signature]
25/05/24
Director

[Handwritten Signature]
13/05/24

Not up as code

[Handwritten Signature]
2/4

[Handwritten Signature]