

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/Educational/2024/SZ/ 303

Dated: 16/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Plot No. B-3, Shankar Garden, Main Najafgarh Road, Metro Pillar No. 616, New Delhi-110058, comprised of Basement (storage), Stilt (parking), ground plus three upper floors (coaching center), owned/occupied by Unacademy Institute have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and verified by the officers concerned of this department on 09.05.2024 in the presence of Sh. Parveen (Unacademy Admin) and that the building is fit for occupancy class "Educational Building" with effect from 16/05/2024. for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....16/05/2024.....at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Authorized Signatory, Unacademy Institute, Plot No. B-3, Shankar Garden, Main Najafgarh Road, Metro Pillar No. 616, New Delhi-110058.
2. Executive Engineer (Bldg.), MCD, Civic Center, Minto Road, New Delhi.

**Following fire safety directives must be adhered to:-**

- The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- All the means of escape shall be kept free of all the type of obstruction all the time.
- All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
- All the fire-fighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
- This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- \* The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/1

## INSPECTION REPORT

1. Name & address of the building : Plot No. B-3, Shankar Garden, Main Najafgarh Road, Metro Pillar No. 616, New Delhi-110058.
2. Building is comprised of : Basement(Storage) Stilt (Parking), ground, First, Second & third floors (Coaching centre)
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous FSC : Nil
6. Fire Safety directives letter no. : Nil
7. Date of Inspection : 09.05.2024
8. Name of the Inspecting officers : Vedpal Chhikara, DO (SW) & R.K. Yadav, ADO (JKP)
9. Name and designation of  
Officer from the building side : Mr. Parveen (Admin Unaccadmy)
10. Year of Construction : 2022
11. Applicant's letter No : Outdoor dairy No. 218 dated 04.04.2024

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks
1	<b>Access to building</b>			
	• Road width	06 m	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits</b>			
	a. Number of Staircases			
	• Upper Floor	2 Nos.	2 Nos.	MR
	• Basement	2 Nos.	2 Nos.	MR
	B. Width of Staircases			
	• Upper Floor	1.5 M each	1.75 & 1.50 m	MR
	• Basement	1.5 M each	1.75 & 1.60 m	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	1.5 m	2.0 m	MR
	f. Door Size	1.20 m	1.20 m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	10 Nos.	10 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR


6	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	1 Nos.	Provided	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	5 MM	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/A	Provided	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	REMOVED	PROVIDED	MR
9	<b>Public address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	• Basement/Stilt	N/A	Provided	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	1 Nos.	Provided	MR
	• Hose Box	01 No	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements.</b>			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level each block			
	➤ Discharge of pump	450 LPM	900 LPM × 2 nos.	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for Fire Fighting.</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 Ltrs	15,000 Ltrs	MR
15	<b>Exit Signage.</b>	Required	Provided	MR


Handwritten marks and signatures at the bottom of the page.




16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule, 2010.

  
 Signature of the Inspecting Officer  
 Name : R.K. Yadav  
 Designation :- ADO (JKP)

  
 Signature of the Inspecting Officer  
 Name : Vedpal Chhikara  
 Designation: - DO (SW)

CFO (SZ)   
 13/5/2014  
 Director   
  
 13/5/2014  
