



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Pet/2024/SZ/ 307

Dated: 16/05/2024

FIRE SAFETY CERTIFICATE

Certified that M/s **Capital Oil Agency** (Retail Outlet of I.O.C.L Petroleum Class A & B) located at Ring Road, Sarojini Nagar, New Delhi-110023, comprised of Ground Floor only, owned/occupied by Capital Oil Agency (Retail Outlet of I.O.C.L Petroleum Class A & B), was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/SZ/Pet/2021/361 dated 28/07/2021. The premise was re-inspected by the officer concerned of this department on 08/05/2024 in the presence of Mr. Vijay Chaudhary (Owner) of the petrol pump and observed that said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/ premise is fit for occupancy class "Storage Group H" (Petrol Pump) with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 16/05/2024 at New Delhi by


K. L. GARG
DIRECTOR
DELHI FIRE SERVICE
01/05/24

Copy to: -

1. Authorized Signatory M/s Capital Oil Agency (Retail Outlet of IOCL Petroleum Class A & B) located at Ring Road, Sarojini Nagar, New Delhi-110023

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1	Name & Address of the Building	M/s Capital Oil Agency (Retail outlet of I.O.C.L. Petroleum Class A & B), Ring Road, Sarojini Nagar, New Delhi- 110023		
2	Type of Occupancy	Storage (Group H) Petrol Pump		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/SZ/Pet/2021/361 Dt. 28/07/2021		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2017/364 Dated 21/12/2017		
7	Date of Inspection	08/04/2024		
8	Name of the Inspecting Officers	Santosh Kumar, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Vijay Chaudhary (Owner)		
10	Year of construction	1995		
11	Applicant letter No.	Email dated 30/04/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old FSC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required	30m	MR
		NA	NA	NA
		NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	NA	NA	NA
	➤ Basement.	NA	NA	NA
	b) Width of Staircase			
	➤ Upper floors	NA	NA	NA
	➤ Basement	NA	NA	NA
	c) Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	NA	NA	NA
	e) Width of corridor	NA	NA	NA
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	10 Nos	12 Nos	MR
	• Types	ABC/CO ₂ /DCP	Provided	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	NA	NA	NA
	• Length of hose-reel hose.	NA	NA	NA
	• Nozzle Diameter	NA	NA	NA

8

a

7.	Automatic fire detection & alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8.	MOEFA			
9.	Public Address System			
		NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground floor.	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	NA	NA	NA
	• Number of Hydrant per floor	NA	NA	NA
	• Hose box.	NA	NA	NA
12.	Yard Hydrants.			
	• Total number of hydrants.	NA	NA	NA
	• Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting/Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump.	NA	NA	NA
	➤ Head of pump.	NA	NA	NA
	➤ Power supply.	NA	NA	NA
	➤ Auto starting of pump.	NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	NA	NA	NA
	➤ Draw-off connection.	NA	NA	NA
	➤ Fire Service Inlet.	NA	NA	NA
	➤ Access to tank.	NA	NA	NA
	• Overhead tank capacity.	NA	NA	NA
15.	No Smoking Signage.	Required	Displayed in Hindi & English	NR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17.	Standby Power Supply	NA	DG Set	NA
18.	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

19.	Fire Control Room.			
	• Detector system panel.	NA	NA	NA
	• Flow switch panel.	NA	NA	NA
	• PA system panel.	NA	NA	NA
	• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.	NA	NA	NA

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/SZ/Pet/2021/361 dated 28/07/2021, renewal under rule 37. of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S Kumar
13/09/24
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

14/5

Such cases are not in purview of DFR Act.

CFO

Director

15/5/24
15/5/24
15/5/24

Sir, F.T letter is put up for your sig. pl.

Director
15/5/24

S Kumar
15/09/24