

c/35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2024/SZ/ 455

Dated: 22/05/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Co-ed. (Model) School, Najafgarh, New Delhi-110043, comprised of two blocks namely Old Block & New Block. Each block is having ground plus one upper floor, owned/occupied by Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2021/433 dated 06.07.2021. The school building was re- inspected by the officer concerned of this department on 14.05.2024 in the presence of Sh. Pardeep Kumar (HOS) and found that the Govt. Sarvodaya Co-ed. (Model) School have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....22/05/2024..... at New Delhi.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Principal, Govt. Sarvodaya Co-ed. (Model) School, Najafgarh, New Delhi-110043
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

- N/15
1. Name & address of the building : Govt. Sarvodaya Co-ed. (Model) School, Najafgarh, New Delhi-43
 2. Building Comprised of : Two Blocks (Ground plus 01 upper floor each)
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC : F.6/DFS/MS/School/2021/433 dated 06.07.2021
 6. Fire Safety directives letter No : F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
 7. Date of inspection : 14.05.2024
 8. Name of Inspecting Officer : A.D.O. R.K. Yadav (JKP)
 9. Name and designation of officers
From the building side : Sh. Pardeep Kumar (HOS)
 10. Year of Construction : Before 2010
 11. Applicant's letter No. : SV/NG/2024 dated 26.03.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 06.07.2021	Provided at site	Remarks MR/NMR
1.	Access to building	Accessible 06 mtrs 4.5 mtrs N/A	Provided Directly accessible from road N/A	MR M/R N/A
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 			
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	03 no.'s in O Blk 01 no. in N blk N/A	Provided N/A	MR N/A
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	b. Width of staircases	150 cms/additional staircase of 75 cms if less than 150 cms N/A	185 to 152, 145 & 100 cms in O blk & 153 cms in N blk N/A	MR N/A
	<ul style="list-style-type: none"> • Upper Floor • Basements 			
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	150 cms	155 cms in O blk & 160 cms in N blk	MR
	f. Door Size	100 cms	96 & 100-97 cms (Double door) few class rooms have single door	MR, being old bldg. and students less than 45 in classes with single door
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural Ventilation provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	20 No's ABC/CO ₂ type ISI marked	Provided Provided ISI marked	MR MR MR

12

hr

N/16

18. Stand
19. Refuge
10

6.	First-Aid Hose Reels			N/A
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			N/A
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A		
10.	Automatic Sprinkler System			N/A
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			N/A
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			N/A
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			N/A
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			N/A
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.	(No Lift)		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A

W/17

	Standby power supply	N/A	N/A	N/A
	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2021/433 dated 06.07.2021, renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

R.K. Yadav
16/5/2024

Signature of Inspecting Officer
Name:- R.K. Yadav
Designation:- ADO (JKP)

DO (South West)
[Signature]
12/5/24

CFO (S2) *[Signature]*
17/5/2024

Director *[Signature]*
17/5/24
[Signature]