



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/Incl./ 313

Dated: 20/05/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Hari Consolidated Pvt. Ltd. located at Plot. No. A- 64/3, industrial Area, G. T. Karnal Road, Delhi-110033 comprised of basement, ground, mezz & first floor owned/occupied by M/s Hari Consolidated Pvt. Ltd. issued Fire Safety Certificate for ground floor only by this department vide this office letter no. F6/DFS/MS/2021/244 dated 04.05.2021. The premise was re-inspection by the officer concerned of this department on 11.05.2024 in presence of Sh. Raman Kr. Saluja (Owner) and observed that all the fire prevention and fire safety arrangements as provided found in good working condition, premises have there for deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class "G-2 Industrial building" with effect from 20/05/2024 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/05/2024 at New Delhi by

(Atul Garg)
Director
Ph:-011-23414000

Copy to:-

1. The Manager, Hari Consolidated Pvt. Ltd., Plot no A64/3, Industrial Area, G. T. Karnal Road, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Hari Consolidated Pvt. Ltd., Plot no. A64/3., G.T K. Road. Industrial Area. Delhi-110033.
2. Type of Occupancy : Industrial Building
3. Composition of building : Basement, Ground, Mazz. & first floor
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2021244 Dated 04.05.2024
6. Fire Safety directives letter No : Nil
7. Date of inspection : 11.05.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Raman Kumar Saluja / Owner
10. Year of Construction : prior to 1983
11. Applicant's letter No. : Online E-mail ID Dated- 23.04.024

Plot Area- 537sqm

S.no.	Minimum Standards on fire prevention and fire safety U/R 33	D M C (Drainage) Bye Laws 1959	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	4'6" (1.37 m) each	1.37m each	MR
	• Basements	4'6" (1.37 m) each	1.37m each	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
e. Width of Corridor	NA	NA	NA	
f. Door Size	1.0m	1.0m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	14nos	14nos	MR
	• Types	ABC/CO2	ABC	MR

	<ul style="list-style-type: none"> • ISI marking 	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Ground Floor	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Each Floor	Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Each Floor	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	Required	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> ➢ Discharge of main Pump 	1620 LPM	1620 LPM	MR
	<ul style="list-style-type: none"> ➢ Head of Main pump 	60m	60m	MR
	<ul style="list-style-type: none"> ➢ Number of main pumps 	01	01	MR
	<ul style="list-style-type: none"> ➢ Jockey Pump out put 	180 LPM	180 LPM	MR
	<ul style="list-style-type: none"> ➢ Jockey pump head 	60m	60m	MR
	<ul style="list-style-type: none"> ➢ Standby Pump out put 	1620 LPM	1620 LPM	MR
	<ul style="list-style-type: none"> ➢ Standby Pump Head 	60m	60m	MR
	<ul style="list-style-type: none"> ➢ Auto Starting/ Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➢ Pump House Access 			
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➢ Discharge of pump 	900 lpm	900 lpm	MR
	<ul style="list-style-type: none"> ➢ Head of the pump 	40mtr	40mtr	MR
<ul style="list-style-type: none"> ➢ Power Supply 	Required	Provided	MR	
<ul style="list-style-type: none"> ➢ Auto Starting of pump 	Required	Provided	MR	
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	25,000 LTR	Provided	MR
	<ul style="list-style-type: none"> ➢ Draw-off connection 	Required	Provided	MR
	<ul style="list-style-type: none"> ➢ Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> ➢ Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> • Overhead Tank capacity 	15,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Required	Provided	MR

N/22

	<ul style="list-style-type: none"> Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. F6/DFS/MS/2020/113 dated 25.02.2020 under rule 37 of the Delhi Fire Service Rules 2010.

Dy. Chief Fire Officer (WZ)

Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN

1911-NW
 13/05/24

~~CFO~~
~~Director~~
 14/5/2024
 11/3/24

~~ADO/RN~~

As approved, F.T. letter is put up for your signature please.

~~Director (DFS)~~
 11/3/24

Signature
 16/05/2024
 Aditya