

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6 DFS/MS/School/2024/SZ/412

Dated: 13/05/2024

FIRE SAFETY CERTIFICATE

Certified that the **School Building** located at Kh. No 262, Chhattarpur Satbari Main Road, (Behind Radians Hotel) New Delhi 110074 comprised of Basement, Ground plus Three upper floors owned/occupied by SD Contractors Private Limited have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concern of this department on 02/05/2024 in the presence of Mr. TC Bandan and that the premises is fit for occupancy class "**Educational, Group-B**" (School) with effect from 13/05/2024 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/05/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.
2. The Authorized Signatory, School Building located at Kh. No 262, Chhattarpur Satbari Main Road, (Behind Radians Hotel) New Delhi 110074.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	School Building at Kh. No 262, Chhattarpur Satbari Main Road, (Behind Radians Hotels) New Delhi		
2	Type of Occupancy	Educational, Group-B		
3	Building Comprised of	Basement, Ground plus Three upper floors		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	NBC Part-IV		
7	Date of Inspection	02-05-2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. T C Bandan		
10	Year of construction	2023		
11	Applicant letter No.	MES02FNOC PR-2024 dated 19/04/2024		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/NBC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	9 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 No	Provided	MR
	➤ Basement floor.	02 No	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr each	1.50 mtr each	MR
	➤ Basement floor	1.50 mtr each	1.50 mtr each	MR
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	1.50 mtr	1.50 mtr	MR
	f) Door size	1.20 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Provided	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	20 Nos Provided	MR
	• Types	ABC / co2	Co2 & ABC Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	02 Nos each	Provided	MR
	• Length of hose-reel hose.	30 mm	Provided	MR
	• Nozzle Diameter	5 m	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-

10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Number of Hydrant per floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump house access. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level <ul style="list-style-type: none"> Discharge of pump Head of pump. Power supply. Auto starting of pump. 	900 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	NA	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		15,000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication in lift car. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's switch. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Lift signage. 	-NA-	-NA-	-NA-
17.	Standby Power Supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location 	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Flow switch panel. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> PA system panel. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Battery backup. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Building floor plan. 	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			
		-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

Manoj

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

Rajesh

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)

Manoj
8/5/2024
Director
[Signature]
8/8/24
[Signature]
ADDO BCP

As approved, F.T. letter is forthup for
your signature pl

[Signature]
9/5/2024

Director
[Signature]
MS/24

[Signature]