

e42

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/SZ/2024/ 423

Dated: 14/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Major Shish Ram Memorial Public School at Village Dariyapur, New Delhi- 110073, Comprised of ground plus two upper floors (Primary block & Secondary block) but school running at ground and first floor only in both blocks, owned/occupied by Major Shish Ram Memorial Public School was issued FSC by this department vide letter no. F.6/DFS/MS/school/SZ/2021/306 dated 05.04.2021. The school building was re-inspected by the officer concerned of this department on dated 06.05.2024 in the presence of Sh. Suresh Yadav (Principal) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 issued by Directorate of Education and that the building/premises {Ground plus one upper floor of both blocks (i.e Primary block & Secondary block ) only} is fit for occupancy class B 'Educational Building' with effect from 14/05/2024 for a period of three years, subject to conditions printed below.

Issued on.....14/05/2024..... at New Delhi.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Principal, Major Shish Ram Memorial Public School at Village Dariyapur, New Delhi- 110073.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

- 1 Name & address of the building : Major Shish Ram Memorial Public School, Village- Dariyapur, New Delhi-110073.
2. Building is comprised of : two blocks namely Primary Block & Secondary Block (each block comprised of ground plus two upper floors but school running at ground and first floor only in both blocks).
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/school/SZ/2021/306 dated 05.04.2021
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 09.05.2024
8. Name of the Inspecting Officers: : ADO R.K. YADAV
9. Name of the designation of Officer from the building side : Sh. Suresh Yadav
10. Year of Construction : 2007 & 2014-15
11. Applicant's letter No : Online email Id [msrmmps133@gmail.com](mailto:msrmmps133@gmail.com) dated 22.04.2024

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirements as per FSC dt. 05.04.2021	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
	Road width	Accessible	04 m	MR, being old case
	Gate width	4.5	Direct accessible from road	MR
	Width of internal road	N.A.	N.A.	N.A.
2	<b>Number, Width, Type and Arrangement of Exits</b>			
a. Number of Staircases Upper Floor Basement B. Width of Staircases Upper Floor Basement c. Protection of exits Fire check door Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door Size				
	2 nos.		2 nos.	MR
	N.A.		N.A.	N.A.
	N.A.		N.A.	N.A.
	1.5 m & .75 m		1.15 m (02 no.'s) in P Blk & 1.40 & 1.25m in S Blk	MR
	N.A.		N.A.	N.A.
	N.A.		N.A.	N.A.
	N.A.		N.A.	N.A.
	1 no.		1 no.	MR
	1.5 m		2.10 m in P Blk & 1.0 to 2.15 m in s Blk	MR, being old case
1 m		.98/1.05 m (Single Door)	MR, being old case	
3	<b>Compartmentation.</b>			
Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers	N.A.		N.A.	N.A.
	N.A.		N.A.	N.A.
	N.A.		N.A.	N.A.
	N.A.		N.A.	N.A.
	N.A.		N.A.	N.A.
4	<b>Smoke Management System.</b>			
Basement Upper floor	N.A.		N.A.	N.A.
	Required		Natural Ventilation Provided	MR

N/C

<b>5.</b>	<b>Fire Extinguisher</b>			
	Total numbers	08 Nos.	08 Nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
<b>6</b>	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	01 nos.	01 nos.	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	05 mm.	Provided	MR
<b>7</b>	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
<b>8</b>	<b>MOEFA</b>	N.A.	N.A.	N.A.
<b>9</b>	<b>Public address System.</b>	N.A.	Provided	N.A.
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
<b>11</b>	<b>Internal Hydrants</b>			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
<b>12</b>	<b>Yard Hydrants.</b>			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
<b>13</b>	<b>Pumping Arrangements.</b>			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump			
	➤ Head of the Pump	450 LPM	450 LPM	MR
	➤ Power supply	40 mtrs	40 mtrs	MR
	➤ Auto Starting of pump	Required	Provided	MR
		Required	Provided	MR


<b>14</b>	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	Provided	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10,000 ltrs	10,000 ltrs	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR

<b>16</b>	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
<b>17</b>	<b>Standby power supply</b>	N.A.	N.A.	N.A.
<b>18</b>	<b>Refuge Area.</b>			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
<b>19</b>	<b>Fire Control Room</b>			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/school/SZ/2021/306 dated 05.04.2021, renewal under the circular no. F.16/Estate/CC/ Fire Safety/2011/3298 to 3398 dated 01.03.2011, is recommended.

**Note:-** As Per undertaking given by the Principal (placed at C-39) School Building is comprised of two stories and the second storey of the building is not in use, and not allowing to sit more than 45 students in each classroom up to first floor.

  
 Signature of the Inspecting Officer  
 Name- R K YADAV  
 Designation- ADO (JKP)

DO (South West)

CFO (SZ)

Director

13/5/2024

*[Handwritten signature]*