

C 22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2024/ 417

Dated: 14/05/2024

FIRE SAFETY CERTIFICATE

Certified that the North MCD Pry. Pratibha Vidyalaya, Sec-15, B-Block, Rohini - 110089, comprised of 02 Blocks, A Block Gr.+ One upper floor, B Blocks Ground floor only owned/occupied by North MCD Pry. Pratibha Vidyalaya was issued fire safety certificate by this department vide letter no F.6/DFS/MS/School/WZ/2021/292 dated 01.04.2021. The premises was re-inspected by the officer concerned of this department on 01.05.2024 in the presence of Smt. Geeta Rani (In-Charge) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have deemed complied with the requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "B" Educational Buildings with effect from 14/05/2024 for a period of three years subject to compliance of the conditions mentioned below.

Issued on 14/05/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to:

1. The Principal, North MCD Pry. Pratibha Vidyalaya, Sec-15, B-Block, Rohini -110089.
2. The Deputy Commissioner, DMC, Sector-5, Rohini, New Delhi-110085.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'j' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ht
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

N/H

NA
NA
NA
NA

| | | | | |
|-----|-------------------------------------------------------------------------|----|----|----|
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Battery backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/WZ/2021/292 dated 01.04.2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

[Handwritten Signature]
21/5/24

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

Dy. CFO(WZ)
[Handwritten Signature]
8/5/24

DCFOI.....8/5/24
Dated.....7/5/24

[Handwritten Signature]
8/5/24
Director

[Handwritten Signature]
ADU/Rektu

FI letter is put up for kind perusal
and signature Dear.

[Handwritten Signature]
Director
14/5/24

[Handwritten Signature]
20/5/24