



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2024 / School / WZ / 460

Dated:

22/05/2024

FIRE SAFETY CERTIFICATE

Certified that the Prudence School (A Unit of Jindal Charitable Society) located at PS-2, C-3 Block, Ashok Vihar, Phase-II, Delhi-110052 comprised of Three Blocks (BL-A=G+3 UF), (BL-B= B+G+3 UF) & (BL-C= B+Stilt+G+3 UF) was issued FSC by this department vide letter No F6/DFS/MS/School/WZ/2021/394 dated 23.06.2021. The premises was re-inspected by the officer concerned of this department on 10.05.2024 in the presence of Ms. Smriti Nanda (Vice-Principal), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy Group B Educational with effect from ..22/05/2024 for a period of three years, in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on ..22/05/2024.. at New Delhi, by


(Atul Garg)
Director

Ph. 011-23414000



Copy to :-

1. The Director, Education, Old Secretariat, Delhi.
2. The Principal, Prudence School, PS-2, C-3 Block, Ashok Vihar, Phase- II, Delhi-110052.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. The basement shall be used as per BBL.

INSPECTION REPORT

1. Name & address of the building : Prudence School (A Unit of Jindal Charitable Society) located at PS-2, C-3 Block, Ashok Vihar, Phase-II, Delhi- 110052.
2. Type of Occupancy : Educational
3. Building Comprised of : 03 Blocks (BL-A= G+3UF), (BL-B= B+G+3 UF) & (BL-C= B+Stilt+ G+3 UF)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/School/WZ/2021/394 Dated- 23/06/2021
6. Fire Safety directives letter No : Old Case
7. Date of inspection : 10/05/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers From the building side : Ms. Smriti Nanda (Vice-Principal)
10. Year of Construction : 2004- 05
11. Applicant's letter No. : PRU/AV/2024/MAY/1120 dated 02/05/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Requirement letter dated 23/06/2021	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	BL-A= 2 BL-B= 2 BL-C=2	BL-A= 2 BL-B= 2 BL-C= 2	MR
	• Basements	BL-B & BL-C= 2 each	BL-B & BL-C= 2 each	MR
	b. Width of staircases			
	• Upper Floor	1.50 m in each block	BL-A= 1.28 m & 1.45 m BL-B= 2 × 1.25 m BL-C= 2 × 1.48 m	MR(old case)
	• Basements	1.5 m & 1 m in each block	BL-B= 2 × 1.44 m BL-C= 2 × 1.50 m	MR (old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01 in each block	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	Required	Exhaust fan provided	MR
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	72 Nos.	86 Nos.	MR
	• Types	ABC/ Co2 Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Required in each block	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA

N-28

	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	
10.	Automatic Sprinkler System			NA
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			MR
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			MR
	• Total number of hydrants	02	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			NA
	• Ground Level		NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	MR
	➤ Number of main pumps	NA	NA	MR
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level		Provided	MR
	➤ Discharge of pump	900 lpm & 180 lpm	Provided	MR
	➤ Head of the pump	50 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			MR
	• Underground tank capacity	Old case	150000 ltrs	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	MR
	• Overhead Tank capacity	BL-A & B= 10,000 ltrs BL-C= 30,000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR

h/ x

Refuge Area.				
	> Total Area	NA	NA	NA
	> Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:			
		NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electrical panel and electric meter are not under the staircase.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended to renew the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2021/394 dated 23/06/2021 under rule 37 of the Delhi Fire Service Rules, 2010.

Rajeev Kumar Sinha
13/5/24

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

Dy Cfo (WZ)

14/5/2024

DCFO/964-1110

Dated 14/05/24

Cfo AS per undertaking, Management has only decided to stop construction than either cranes stoped & sealed or not - inspect and put up report accordingly

15/5/2024

Dy Cfo (WZ)

15/5/2024

Ado (Banana) Sr. I have Inspects the building again on 16/5/24. The management has stopped construction and not in ~~used~~ ^{used}. The photograph is placed opposite,

DCFO/964-1110
16/5/2024

Dy Cfo (WZ)

16/5

Cfo *16/5/2024* *Director* *16/5/24*

Rajeev Kumar Sinha
16/5/24