

e-24



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2024/ School/ 436

Dated: 17/05/2024

FIRE SAFETY CERTIFICATE

Certified that the **Rajkiya Pratibha Vikas Vidyalaya**, located at **Nai Basti, Kishan Ganj, New Delhi** is comprised G+ 02 upper floor, the premises, was inspected by the officer concerned of this department on 08/05/24 in the presence of Principal and found that the said school building has complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and that the premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from17/05.....2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on17/05/2024... at New Delhi by:


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner , MCD Civic Centre , New Delhi
2. Director of Education, Govt. of NCT, Delhi.
3. The Principal, Raikiya Pratibha Vikas Vidyalaya, Nai Basti, Kishan Ganj, New Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. Any flammable material for interior decoration shall strictly prohibited.

1/12
INSPECTION REPORT

1. Name & address of the building:- Rajkiya Pratibha Vikas Vidyalaya at Nai Basti, Kishan Ganj, New Delhi.
 2. Type of occupancy:- Educational Group-B
 Educational Building Gr. + 02 Upper floor fresh
 3. Type of case:-
 4. Details of previous FSC:-
 5. Fire safety directives No.- N/A
 6. Date of inspection:- 08/05/24.
 7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
 8. Name & designation of officer
 From the building side:- Principal
 9. Year of construction:- 1970
 10. Applicant's letter No:- letter no RPVV/KG/2024/89 dated 16/04/24.

Old Case

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement Exiting fire safety arrangements | Provided at site | Remarks MR/NMR |
|-------|---|--|---------------------|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | 06 mtr. | 06 mtr. | MR |
| | 2) Gate width | NA | NA | NA |
| | 3) Width of internal road | NA | NA | NA |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | 03 | 03 | MR |
| | 2. Basements | NA | NA | NA |
| | B. Width of staircase | | | |
| | 1. Upper floors | 1.5 Mtr & 0.75 mtr. | 1*1.5 & 2*1.25 mtr. | MR |
| | 2. Basements | NA | NA | NA |
| | C. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | | | |
| | | 01 | 01 | MR |
| | E. Width of corridor | | | |
| | | N/A | N/A | N/A |
| | F. Door size | | | |
| | | 1 mtr. | 1 mtr. | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements (190 SQM) | NA | NA | NA |
| | 2) Upper floors | 12 ACPH | natural | MR |
| 5. | Fire Extinguishers | | | |
| | 1) Total numbers | 10 Nos. | 10 Nos. | MR |
| | 2) Types | ABC & CO2 | ABC, CO2 & W.CO2 | MR |
| | 3) ISI marking | Required | Provided | MR |

M/V

| | | | | |
|-----|--|----------|--------------|------|
| 6. | First-Aid Hose Reel | | | |
| | 1) Total number of each floor | 01 | 01 ✓ | MR |
| | 2) Length of hose reel hose | 30 mtr. | 30 mtr. | MR |
| | 3) Nozzle diameter | 05 mm | 05 mm | MR |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors | N/A | N/A | N/A |
| | 2) Location of main panel | N/A | N/A | N/A |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | N/A | N/A | N/A |
| | 5) Hooter's Location | N/A | N/A | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement (less than 200 SQM) | N/A | N/A | N/A |
| | 2) Upper floors | N/A | N/A | N/A |
| | 3) Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | N/A | N/A | N/A |
| | 2) Number of hydrants per floor | N/A | N/A | N/A |
| | 3) Hose box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangement | | | |
| | 2) Ground level | N/A | N/A | N/A |
| | a) Discharge of main pump | N/A | N/A | N/A |
| | b) Head of main pump | N/A | N/A | N/A |
| | c) Number of main pump | N/A | N/A | N/A |
| | d) Jockey pump out put | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 3) Terrace level | | | |
| | a) Discharge of pump | 450 LPM | 450 LPM | MR ✓ |
| | b) Head of pump | 40 mtr | 40 mtr | MR |
| | c) Power supply | Required | Provided | MR |
| | d) Auto starting of pump | Required | Provided | MR |
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | N/A | 20,000 ltrs. | N/A |
| | a) Draw-off connection | N/A | N/A | N/A |

2/15

| | | | | |
|-----|--|--------------|----------------|-----|
| | b) Fire service inlet | N/A | N/A | N/A |
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | 10,000 ltrs. | 10,000 ltrs. / | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | N/A | N/A | N/A |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: | | | N/A |

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may issue the FSC. Accordingly reply letter is prepared and put up for kind perusal and approval pl.

Signature of the Inspecting Officer



Name: - Ravinder Singh
Designation: - ADO (CC)

DOP/CD

18/5/24

Dy. C.A. (1002)

13/05/24

C.F/O - [Signature]
14/5/2024

Director
[Signature]
15/5/24

[Signature]