

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6/DFS/MS/BNQT/2024/SZ/26

Dated: 07/05/2024

FIRE SAFETY CERTIFICATE

Certified that the **M/s Royal Eastern Hospitality Pvt. Ltd** at T-540, Min Maharishi Dayanand Marg, Malviya Nagar, New Delhi-110017 comprised of ground plus one temporary pucca construction at 1st floor Owner/occupied by **Royal Eastern Hospitality Pvt. Ltd** was issued fire safety certificate by this department vide letter no. F6/DFS/MS/BQNT/SZ/2021/227 dated 14/09/2021. The Banquet Hall was re-inspected by the officer concerned of this department on 25/04/2024 in the presence of Mr. Manoj and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** (Banquet Hall) and validity upto 31/03/2027 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/05/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Addl. Commissioner of Police (Lic/Branch) 1st Floor PS Defence Colony, New Delhi 110049. (Ref. MHA Portal ID 2024041204919 dated 12/04/2024)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Royal Eastern Hospitalities Pvt. Ltd at T-540 Min, Maharishi Dayanand Marg, Malviya Nagar, New Delhi-110017		
2	Type of Occupancy	Assembly 'Group-D' (Banquet Hall)		
3	Building comprised of	Ground plus one upper floor (temporary pucca construction at 1 st floor)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/BQNT/SZ/2021/227 dated 14/09/2021		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	25/04/2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Manoj		
10	Year of construction	1956		
11	Applicant letter No.	MHA Portal ID 2024041204919 dated 12/04/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	09 mtr	18 m	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	NA	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	02	02	MR
	• Basement floor	-NA-	N/A	N/A
	b. Width of Staircase			
	• Upper floors	1.25 m / 1 m	1.25 m & 1 m	Old case
	• Basement floor	-NA-	N/A	N/A
	c. Protection of exits			
	• Fire check door	-NA-	N/A	N/A
	• Pressurization	-NA-	N/A	N/A
	d. No. of continuous staircase to terrace	02	02	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3	Compartmentation.			
	• Fire check door.	-NA-	N/A	N/A
	• Sealing of electrical shafts.	-NA-	N/A	N/A
	• Fire rating of shaft door.	-NA-	N/A	N/A
	• Water curtain	-NA-	N/A	N/A
	• Fire dampers.	-NA-	N/A	N/A
4	Smoke Management system.			
	• Basement	-NA-	N/A	N/A
	• Upper floors	-NA-	N/A	N/A
5	Fire Extinguishers.			
	• Total numbers		20 No's	MR
	• Types	ABC / CO2	ABC & Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Required 02 Nos	02 Nos Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-

M

7/19

<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hoofer's location 	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-

8	MOEFA	Required	Provided	MR	
9	Public Address System	-NA-	-NA-	-NA-	
10	Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basement / Lower ground floor Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
11	Internal Hydrants.				
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR	
		02 Nos	Provided	MR	
		02 Nos	Provided	MR	
12	Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
13	Pumping arrangements.				
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting / Manual Stopping. ➤ Pump House Access Terrace Level ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		900 LPM	900 LPM	MR	
		40 mtr	40 m	MR	
		Required	Provided	MR	
		Required	Provided	MR	
	14	Captive water storage for Fire Fighting.			
		<ul style="list-style-type: none"> Underground tank capacity. ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-	
		Required	Provided	MR	
		-NA-	-NA-	-NA-	
		5,000 Ltrs	10,000 Ltrs	MR	
15	Exit Signage.	Required	Provided	MR	
16	Provision of Lifts.				
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
17	Standby Power Supply	Required	Provided	MR	
18	Refuge Area				
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	

n/20

-NA-
VA-
4-

Fire Control Room.				
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/BQNT/SZ/2021/227 dated 14/09/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

ms

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

RS
29/11/2021

CFO (HQ)

H Singh
29/11/2021

Director
MS
30/11/21
AD/BCP

As approved, F-1 letter is put up for your signature pl.

Director
MS
21/5/22

RS
21/5/2022

ms cell

MS

AD/BCP
MS

Uploaded
29/11/21