

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. D6/DFS/MS/SZ/2024/School/420

Dated: 14/05/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Salwan Boys Sr. Sec. School Located at Old Rajinder Nagar, New Delhi-110060 comprised of Ground + 1 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/SZ/2021/113, dated:11/02/2021. The premises was re inspected by the officer concerned of this department on 29/04/2024 in the presence of Sh. Naresh Kumar (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298 – 3398 Dated 17-01-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 14/05/2024 for a period of three years.

Issued on 14/05/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:

- 1. The Principal, Salwan Boys Sr. Sec. School Located at Old Rajinder Nagar, New Delhi-110060.
- 2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

- 1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3. The trained staff should be available round the clock.
- 4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6. Basement shall be used strictly as per building bye laws.
- 7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
- 8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

2-18

1. Name & address of the building: Salwan Boys Sr. Sec. School Located at Old Rajinder Nagar, New Delhi-110060.
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/SZ/2021/113, dated:11/02/2021
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 29-04-2024
7. Name of the Inspecting Officer : Uđai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Naresh Kumar (Principal)
9. Year of Construction : Before 2007
10. Applicant's letter No. : Email dated 16/04/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/14, N/15 & N/16	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtr	Provided	MR
	• Gate width	4.5m	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	Provided	MR
	• Basements	N/A	N/A	NA
	b. Width of staircases			
	• Upper floors	1.5m if less than 1.5m additional stair of 0.75m width is required	1.5m & 1.40m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	01 No.	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1 mtr	104 cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

[Handwritten Signature]

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 nos.	Provided	MR
		ABC & CO ₂	ABC & CO ₂	MR
		ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13				
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/SZ/2021/113, dated:11/02/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Office

Name

Designation

[Handwritten Signature]
 Uday Vir Singh
[Handwritten Designation]

[Handwritten Signature]
 11/5/24

[Handwritten Signature]
 11/5/2021

[Handwritten Signature]
 Director

[Handwritten Signature]