



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 452

Dated: 22/05/2024

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidyalaya (I.D-1309031)** located at **Adarsh Nagar, Delhi-110033** comprised of **04 blocks (Ground + First floor only)** owned/occupied by **Sarvodaya Kanya Vidyalaya** was granted FSC by this department vide letter no. **F6/DFS/MS/School/2021/WZ/212 dated 11.03.2021**. The premises was re-inspected by the officer concerned of this department on **02.05.2024** in presence of **Smt. Sunita Rani (Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by **Director of Education vide letter no 3298-3398 dated 01.03.2011** and the building/ premise is fit for occupancy class Group B Educational with effect from ...22/05/2024... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 22/05/2024..... at New Delhi by

(Atul Garg)
Director
Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Sarvodaya Kanya Vidyalaya, Adarsh Nagar, Delhi-110033

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, Adarsh Nagar, Delhi-110033. (I.D-1309031)
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : 04 blocks- Ground + First floors only
5. Details of previous NOC : F6/DFS/MS/School/2021/WZ/212 dated 11.03.2021
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
7. Date of inspection : 02.05.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Smt. Sunita Rani , Principal
9. Year of Construction : 2000
10. Applicant's letter No. : Online E-Mail I.D dated : 26.04.2024

	Minimum Standards on fire prevention and fire safety U/R 33	Director. Of Education Circular dated 01.03.2011 requirements	Provided at site	Remarks MR/NMR	
1	Access to building				
		6m	6m	MR	
	<ul style="list-style-type: none"> • Road width • Gate width 	4.5m	4.50m	MR	
	<ul style="list-style-type: none"> • Width of internal road 	NA	NA	NA	
2	Number, Width, Type & Arrangement of Exits				
	a. Number of staircases				
	<ul style="list-style-type: none"> • Upper Floors • Basements 	08 NA	08 NA	MR NA	
	b. Width of staircases				
	<ul style="list-style-type: none"> • Upper Floors • Basements 	150 m NA	06 nos. of 1.35m 02 nos. of 1.40 m NA	MR (old case) NA	
	c. Protection of exits				
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA	
	d. No. of continuous staircases to terrace	NA	NA	NA	
	e. Width of Corridor	NA	NA	NA	
	f. Door Size	1m	1m	MR	
	3	Compartmentation.			
		<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4 Smoke Management System.					
<ul style="list-style-type: none"> • Basements • Upper floors 		NA NA	NA NA	NA NA	
5		Fire Extinguishers			
		<ul style="list-style-type: none"> • Total numbers 	16nos	17nos	MR

Op

	<ul style="list-style-type: none"> Types ISI marking 	ABC/Co2	ABC	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> Nozzle diameter 	NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	N/A	NA
		NA	N/A	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			

MR

	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	N/A	NA
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/School/2021/WZ/212 dated: 11.03.2021.

Dy. Chief Fire Officer (WZ)

Signature of the Inspecting Officer



Name:- C.L. Meena

Designation:- Asst. Div. Officer (RN)


There is no file pending before received this file.

DCFO/973-A/112

Dated: 10/05/24


 10/5

 Director
 13/5/2024

Ameyan


 08/05/2024


 08/05/2024