

C17

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No. F6/DFS/MS/School/WZ/2024/ 410

Dated: 10 / 05 / 2024

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya co-ed senior secondary School located at Jaidev Park, New Delhi -110026. Old building (School ID-1515001), comprised of ground + 03 Upper Floors, owned/occupied by Sarvodaya co-ed senior secondary School, was issued FSC by this department vide letter No. F6/DFS/MS/School/2015/1446 dated 11/08/2015. The premises was re - inspected by the officer concerned by this department on 25/04/2024 in the presence of Sh. Vinod Kumar (Principal) and found that the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules, 2010 and found that the building / premises is fit for occupancy class "Educational" (Group -B) ( For G + 03, Old Building only ) with effect from ..10/05/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on ..10/05/2024... at New Delhi.

  
(Atul Garg)  
Director

**Copy to:**

1. The Principal, Sarvodaya Co-ED senior secondary School located at Jaidev Park, New Delhi -110026. (School ID-1515001) Email Id- svjaidevpak@gmail.com
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. **This FSC is valid for Ground + 03 upper floors (Old Building) Only.**

**INSPECTION REPORT**

1. Name & address of the building	Sarvodaya Co-ED senior secondary School located at Jaidev Park, New Delhi -110026.Old building (School ID-1515001)
2. Type of Occupancy	Educational (ground +03 upper floors)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/2015/1446 dated 11/08/2015
5. Fire Safety directives letter No	DOE Circular 3298-3398 dated 01/03/2011
6. Date of inspection	25/04/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Vinod Kumar (Principal)
9. Year of Construction	1988 As per previous Insp. report dtd.- 24/07/2015
10. Applicant's letter No.	Letter no.- SV/JDP/2024/194 dated 28/03/2024

The Said school is running in ground + 03 upper floors, was issued FSC by this department vide letter No. F6/DFS/MS/School/2015/1446 dated 11/08/2015.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6.5 m	Provided	MR
	• Gate width	4 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	G to FF=01, GF to TF=02 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	G to FF= 4.80m & GF to TF= 1X 1.38m, 1 X 1.31m	MR Old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	Required	02 Provided	MR
	f. Width of Corridor	1.5m	2.38m Provided	MR
	g. Door Size	1m	2X1m Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	45	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	Provided	NA
9	<b>Public Address System.</b>	NA	Provided	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	02 Provided	NA
	• Hose Box	NA	02 Provided	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NR	NR	NR
	➤ Draw-off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

16 Provision of Lifts.				
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	NA	NA	NA
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

62 | ADO | MN  
26 | 04 | 2024

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules FSC issued by this department vide letter no.- F6/DFS/MS/School/2015/1446 dated 11/08/2015, renewal under rule 35 of the Delhi Fire service rules 2010 it is recommended.

*Sir no file pendency.*  
*(A/C 20/12)*

*[Signature]*  
26/4/2024

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

*[Signature]*  
29/4

*cfo*  
*[Signature]*  
29/4/2024

*Director / [Signature]*  
30/4/2024

*[Signature]*  
AOD/MN

FOI-229.....  
Date: 29/04/2024

*Sir, F. T is put up for your kind personal & signature please.*

*[Signature]*  
06/05/2024