

C38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/SZ/2024/ 419

Dated:- 14 /05/2024

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Bal Vidyalaya (Id-1720001) located at Delhi Cantt, Tigris Road, Delhi – 110010 comprised of Ground + 02 upper floors (old Block) & Three New Blocks all are Ground + one upper floor only owned/occupied Sarvodaya Bal Vidyalaya, was granted FSC by this department vide letter No. F6/DFS/MS/School/2020/SZ/561 dated 17/12/2020. The premises was re-inspected by the officers concerned of this department on 04/05/2024 in the presence of the Dr. Ajit Singh Yadav (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class Group B “Educational Building” Sub-Div. B-I with effect from ~~14.10.2024~~ 14.10.2024 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on ..14/05/2024 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service

To,

1. The Principal,
Sarvodaya Bal Vidyalaya (Id-1720001), Delhi Cantt, Tigris Road, Delhi – 110010.
2. The Director of Education,
Govt. of NCT, of Delhi, Old Secretariat, Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry”.

INSPECTION REPORT

1. Name & address of the building:- Sarvodaya Bal Vidyalaya (Id-1720001) at Delhi Cantt, Tigris Road, Delhi -10
2. Type of occupancy:- Educational Building
Gr.+ 02 upper floors (Old Block)
Three New Block (Ground + one upper floor)
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/2020/SZ/561 dated 17/12/2020
5. Fire safety directives No.- N/A
6. Date of inspection:- 04/05/2024
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (DO/SD)
8. Name & designation of officer
From the building side:- Dr. Ajit Singh Yadav (Principal)
1939 & 2015
9. Year of construction:- SBV/DC/2024-25/58 dated 26/04/2024
10. Applicant's letter No:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	DOE Circular	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	6 mtr.	9 mtr.	MR
	2) Gate width	4.5 m	4.5 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos.	02 nos.	MR
	2. Basements	NA	NA	NA
	B. Width of staircase			
	1. Upper floors	1.5 mtr	1.5 m & 1.35 m	MR
	2. Basements	NA	NA	NA
	C. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	01 nos.	01 nos.	MR
	E. Width of corridor	1.5 mtr	1.5 mtr	MR
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	NA	NA	NA
	2) Sealing of electrical shafts	NA	NA	NA
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	NA	NA	NA
	2) Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	1) Total numbers	19 Nos.	21 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	04 nos.	04 nos.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	05 mm	05 mm	MR

7. Automatic Fire Detection & Alarming System				
	1) Type of detectors	NA	NA	NA
	2) Location of main panel	NA	NA	NA
	3) Location of repeater panel	NA	NA	NA
	4) Alternate source of power	NA	NA	NA
	5) Hooter's Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10. Automatic Sprinkler System				
	1) Basement	NA	NA	NA
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11. Internal Hydrants				
	1) Size of riser/down-comer	NA	NA	NA
	2) Number of hydrants per floor	NA	NA	NA
	3) Hose box	NA	NA	NA
12. Yard Hydrants				
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13. Pumping Arrangement				
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPMx2	MR
	b) Head of pump	40 m	40 m	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14. Captive Water Storage for Fire Fighting				
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 liter	10,000 liter	MR
15.	Exit Signage.	Required	Provided	MR
16. Provision of Lifts.				
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

2/22

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/School/2024/SZ/94 dated 01/03/2024 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2020/SZ/561 dated 17/12/2020 renewal under Rule 35 of the Delhi Fire Service rules 2010. is recommended.

M.K. Sharma
Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- DO (SD)

CFO/HQ
[Signature]

[Signature]
7/5/24

[Signature]
7/5/24

[Signature]

[Signature]
7/5

F.T. letter is put up for sig. pl

[Signature]
7/5/24

[Signature]
7/5