

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/NDZ/2024/ 317

Dated: 21/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Anand Filling Station, at Baba Kharak Singh Marg, Opp Gurudwara Bangla Sahib New Delhi, comprised of ground floor, was issued NOC vide letter no. F5/(12)/DFS/2002/122 dated 09.04.2002. Now, the premises was re-inspected by the officer concerned of this department on 09/05/24 in the presence of Mr. Sarvinder Singh and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Hazardous (Group J) with effect from 21/05/2024 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 printed below.


  
(Anand Marg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police, licensing, Defence Colony Police Station, New Delhi
2. The Director Health license /MOH, Room No 1002 Palika Kendra, New Delhi.
3. The Manager, M/S Anand Filling Station, at Baba Kharak Singh Marg, Opp Gurudwara Bangla Sahib, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. This FSC is valid only for petrol filling station.
2. All the fire safety arrangements provided in the building shall be maintained in good working condition.
3. "No Smoking" and "Not to use Mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.
4. All the petroleum rules and comments of the Chief Inspector of Explosive should strictly adhered to and no trade susceptible to cause Ignition Petroleum vapors by generating heat, mechanical/electric spark should be allowed within the premises and its vicinity.
5. The working employed at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
6. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
7. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is strictly prohibited.

Recd.  
  
27/05/2024

## INSPECTION REPORT

1. Name & address of the building M/S Anand Filling Station, at Baba Kharak Singh Marg, Opp Gurudwara Bangla Sahib New Delhi.
2. Type of occupancy:- Hazardous Group J  
Ground
3. Type of case:- Renewal
4. Details of previous FSC:- F5/(12)/DFS/2002/122 dated 09.04.2002
5. Fire safety directives No.- N/A
6. Date of inspection:- 09/05/24
7. Name of the inspecting officer:- Sh.Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Mr. Sarvinder Singh
9. Year of construction:-
10. Applicant's letter No:- letter no. NIL dated 11.04.2024.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement /Existing arrangements	Provided at site	Remarks MR/NMR
<b>1. Access to Building</b>				
	1) Road width	06 mtr.	15 mtr.	MR
	2) Gate width	Accessible	Accessible Directly	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2. Number, Width Type &amp; Arrangement of Exits</b>				
<b>A. Number of staircases</b>				
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
<b>B. Width of staircase</b>				
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
<b>C. Protection of exits</b>				
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
<b>D. No. of continuous staircase to terrace</b>				
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
<b>3. Compartmentation</b>				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4. Smoke Management System</b>				
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
<b>5. Fire Extinguishers</b>				
	1) Total numbers	02 nos Nos.& 06fire bucket	06 nos & 06 nos fire bucket	MR
	2) Types	ABC	ABC,	MR
	3) ISI marking	Required	Provided	MR
<b>6. First-Aid Hose Reel</b>				
	1) Total number of each floor	N/A	N/A	N/A

✓

N/A

	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
<b>15.</b>	<b>No Smoking Signage English &amp; Hindi</b>	Required	Provided English & Hindi	MR

20

W/S

16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any: Provided Fire buckets with sand.</b>			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew NOC/ FSC to said petrol filling station. Accordingly, DFA is prepared and put up for kind perusal and sig. please.


Signature of the Inspecting Officer



Name: - Ravinder Singh  
Designation: - ADO (CC)

DO/CD


  
16/5/24

  
Dy. CCS (1002)

  
16/5/24

C.F.O.

  
17/5/24

  
17/5/24



As per proposed DFA put up for kind perusal and  
signature please.

  
17/5/24

