

e10

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2024/ 457

Dated: 22/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Beacon Global School**, Plot No.723 & 724, Ext. Lal Dora, Pooth Khurd, Delhi-110039, comprised of **Ground + 01 upper floor** owned/ occupied by the **Beacon Global School** have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on **15.05.2024** in the presence of **Mr. Bhupender Singh** and that the building/ premise is fit for occupancy **Group B Educational** with effect from 22/05/2024 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 22/05/2024 at New Delhi by

  
(Atul Garg)  
**DIRECTOR**  
Ph; 011-23414000

**Copy to:**

1. The Principal, Beacon Global School, Plot No.723 & 724, Ext. Lal Dora, Pooth Khurd, Delhi-110039.
2. The Director of Education, Old Secretariat, Delhi

**Conditions for validity of Fire Safety Certificate;**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Ru](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[les/ http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

4/3

## INSPECTION REPORT

1. Name & address of the building	Beacon Global School, Plot No.723 & 724, Ext. Lal Dora, Pooth Khurd, Delhi-110039.
2. Type of Occupancy	Educational
3. Type of Case	New Case (Ground + 01 upper floor)
4. Details of Previous NOC	-NA-
5. Fire Safety directives letter No	Director of Education Cir. dated 01.03.2011.
6. Date of inspection	15.05.2024.
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)
8. Name and designation of officers From the building side	Mr. Bhupender Singh
9. Year of Construction	-NA-
10. Applicant's letter No.	OD No.24.04.2024

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Education Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	6.0m	6.0m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	<b>b. Width of staircases</b>			
	• Upper Floor	1.5m	2 x 1.5m	MR
	• Basements	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	-NA-	-NA-	-NA-
	<b>e. Width of Corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door Size</b>	-NA-	-NA-	-NA-
3.	<b>Compartmentation</b>			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilation	-NA-
5.	<b>Fire Extinguishers</b>			
	a) Total numbers	6nos.	06nos.	MR
	b) Types	ABC/CO2	ABC-06nos.	MR
	c) IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	a) Total numbers on each floor	-NA-	Provided	-NA-
	b) Length of hose reel hose	-NA-	Provided	-NA-
	c) Nozzle diameter	-NA-	Provided	-NA-

N/4

Fire Con  
19.  
b) Lo  
a) To

<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
<b>8.</b>	<b>MOEFA</b>	-NA-	-NA-	-NA-
<b>9.</b>	<b>Public Address System</b>	-NA-	-NA-	-NA-
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
<b>11.</b>	<b>Internal Hydrants</b>			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
<b>12.</b>	<b>Yard Hydrants</b>			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
<b>13.</b>	<b>Pumping Arrangements</b>			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	-NA-	450lpm	-NA-
	➤ Head of the pump	-NA-	40m	-NA-
	➤ Power Supply	-NA-	Provided	-NA-
	➤ Auto Starting of pump	-NA-	Provided	-NA-
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	-NA-	10,000ltr	-NA-
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
<b>17.</b>	<b>Standby power supply</b>	-NA-	-NA-	-NA-

26

Refuge Area.			
a) Total Area	-NA-	-NA-	-NA-
b) Location	-NA-	-NA-	-NA-
<b>19. Fire Control Room</b>			
a) Detector System Panel	-NA-	-NA-	-NA-
b) Flow Switch Panel	-NA-	-NA-	-NA-
c) PA System Panel	-NA-	-NA-	-NA-
d) Battery backup	-NA-	-NA-	-NA-
e) Building Floor Plans	-NA-	-NA-	-NA-
<b>20. Special Fire Protection System for Protection of special Risks, if any:</b>	-NA-	-NA-	-NA-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in **Director of Education Circular**, and removal of shortcomings issued vide letter no. 157 dated 03.04.2024, under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*(Signature)*  
16/5/24

Signature of the Inspecting Officer  
Name        Ajay Kumar Sharma  
Designation ADO(Rohini)

Dy. CFO(WZ)

*(Signature)*  
16/5

*(Signature)*

*(Signature)*  
17/5/2024

Director

*(Large Signature)*  
18/5/24

*(Signature)*  
Ajay Kumar

DCFOI..... 924  
Dated..... 16/5/2024

For letter is put up for kind perusal  
Please.

*(Signature)*  
Director

*(Signature)*  
12/5/24