

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/CGHS/SZ/2024/332

Dated: 03/06/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Progressive Enclave CGHS Ltd. Located at Plot No-03, Sector-03, Dwarka, New Delhi-110078, having 03 blocks comprised of stilt/ground + 06/08 Upper Floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/CGHS/2018/SZ/2754, dated 28/12/2018. The premise was re inspected by the officer concerned of this department on 21/05/2024 in the presence of. Sh. S.C Gupta (Society member) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Residential Building" Group A-4 with effect from 03/06/2024 for a period of **five years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/06/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
03/06/2024

Copy to:

1. The President, Progressive Enclave CGHS Ltd. Located at Plot No-03, Sector-03, Dwarka, New Delhi-110078.
2. The Joint Director (Building) DDA, Vikas Sadan, INA, Delhi-110023.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

11/20
INSPECTION REPORT

1. Name & address of the building: Progressive Enclave CGHS Ltd. Located at Plot No-03, Sector-03, Dwarka, New Delhi-110078.
2. Type of Occupancy : Residential Building "A" (Apartment)
3. Type of Case : Renewal 03block= stilt/ground+06 to 08 upper floors
4. Details of previous NOC : F6/DFS/MS/CGHS/2018/SZ/2754, dated 28/12/2018
5. Fire Safety directives Letter No. : F6//DFS/MS/CGHS/97/1022, dated 19/08/1997
6. Date of inspection : 21/05/2024
7. Name of the Inspecting Officer : Sh. Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. S.C Gupta (Society member)
9. Year of Construction : 2004
10. Applicant's letter No. : Email, dated-08/05/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As Per N/14, N/15 & N/16	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	Provided	MR
	• Gate width	4.5 mtrs	Provided	MR
	• Width of internal road	6 mtrs	5.6m to 6 m	MR (Being old case)
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	2 no. each block	Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.25 m	1m & 1.25m	MR (old case)
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01 each block	Provided	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR

20/5

Captive water Storage for fire fighting				
14.	Under ground tank capacity	2,00,000 ltrs	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltr each block	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/CGHS/2018/SZ/2754, dated 28/12/2018 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved FSC may be issued.

Signature of the Inspecting Officer
 Name
 Designation

[Handwritten Signature]
 24/5/24
[Handwritten Name]
 AD-10/5/4

[Handwritten Signature]
 24/5/24
 CFQ/SZ
 27/5/2024
 Director
[Handwritten Signature]
 27/5/24

[Handwritten Signature]
 AD-10/5/4