

432

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

No.F.6/DFS/MS/School/2024/SZ/466 NEW DELHI-110 001.

Dated: 24/05/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Boys Sr. Sec. School (Id- 1822065) at Jharoda Kalan, New Delhi-110072, comprised of ground floor plus three upper floors owned/occupied by Govt. of NCT of Delhi have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010, and verified by the officer concerned of this department on 14.05.2024 in the presence of Mr. Ravi Kumar (Engineer) and found that the building/ premises is fit for occupancy class B 'Educational Building' with effect from 24/05/2024.. for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....24/05/2024.....at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Principal, Govt. Boys Sr. Sec. School at Jharoda Kalan, New Delhi-72 (School Id- 1822065).
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi.
3. Assistant Engineer (E), Edu. Sub-Divn. M1-1, (N), PWD, ITI Campus, Pusa, New Delhi-12.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

12/14

INSPECTION REPORT

1. Name & address of the building : Govt. Boys Sr. Sec. School (Id- 1822065), at Jharoda Kalan, New Delhi- 110072
2. Building comprised of : New Building SPS Block having Ground plus three upper floors.
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 14.05.2024
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Mr. Ravi Kumar (Engineer)
10. Year of Construction : 2022-23
11. Applicant's letter No. : 54(SPS School)/PWD Edu. Sub- Divn. M1-1(N)/2024-25/22 dated 12.04.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5 m N/A	Provided 06 m N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	04 No.'s N/A	04 No.'s N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 m N/A	1.70 m each N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Two	M/R
	e. Width of Corridor	1.50 m	1.75 m	M/R
	f. Door Size	1.0 m	1.20 m	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers at each floor • Types • IS marking 	08 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	06 nos. 30 m 5 mm	06 nos. Provided Provided	M/R M/R M/R

[Handwritten signatures and initials]

N/15

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		06 Nos.	06 Nos.	MR
		01 Nos.	01 Nos.	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		450 LPM	450 LPM (02 no.'s)	M/R
		40 mtrs	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10000 ltrs	10,000 ltrs (2 nos.) Total 20,000 ltrs	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
		No Lift		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
		N/A	N/A	N/A

10/16

18. Refuge Area.				
	> Total Area	N/A	N/A	N/A
	> Location	N/A	N/A	N/A
19. Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20. Special Fire Protection System for Protection of special Risks, if any:				
		N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under Rule 35 of the Delhi Fire Service Rules 2010, it's recommended to grant Fire Safety Certificate.

[Handwritten Signature]
22/5/2024

Signature of Inspecting Officer
Name: - R.K. Yadav
Designation:- Asstt. Divisional Officer

DO (South West)

[Handwritten Signature]
17/5/2024

[Handwritten Signature]
17/5/2024

[Handwritten Signature]
17/5/24

[Handwritten Signature]
R.K.Y

F T batteries put up for agm please

DIRECTOR
[Handwritten Signature]
22/5/24

[Handwritten Signature]
22/5/2024