

497

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/EH/MN/2024/ 141

Dated: 13/05/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s. Hira Sweets & Confectionary Private Limited located at A-2, Ground Floor, Najafgarh Road, Kirti Nagar, New Delhi 110015 in a building comprised of Basement, Ground & three upper floors Owned/Occupied by M/s. Hira Sweets & Confectionary Private Limited was issued Fire Safety Certificate vide Letter No. F6/DFS/MS/EH/MN/2021/105 dated 20/04/2021, The premises was re-inspected by officer concerned of this department on 01/05/2024 in the presence of Sh. Ratna Prakash Kar and found that the said building/Premises have deemed complied with the fire prevention & fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rule 2010 & the said premises is fit for occupancy class "Assembly" Group - D (Ground Floor Only) and valid upto 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 condition mentioned below.

Issued on ... 13/05/2024 ... at New Delhi by.

(Atul Garg)
Director

Copy to:

1. M/s. Hira Sweets & Confectionary Private Limited located at H. N. A-2, Ground Floor, Upper basement, Kirti Nagar New Delhi - 110015.
2. Dy. Health Officer, MCD, West Zone, Vishal Enclave, Rajouri Garden, New Delhi - 110027. (dhowestzone@gmail.com)
3. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (adlcp.lic-dl@nic.in)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. **This NOC is valid for Ground floor only.**

INSPECTION REPORT

1. Name & address of the building	Hira Sweets and confectionary Pvt. Ltd. located at A-2, Ground Floor, Najafgarh Road, Kirti Nagar, New Delhi-110015.
2. Type of Occupancy	Assembly/ Restaurant (Eating House)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/EH/MN/2021/105 dated 20/04/2021
5. Fire Safety directives letter No	Nil
6. Date of inspection	01/05/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Ratna Prakash Kar
9. Year of Construction	2010 (As per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2024041505191 dated 15/04/2024

The Said Restaurant is running at Ground Floor in a building comprised of Basement + Ground + 03 upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA (GF)	NA
	• Basements	N/A	N/A	MR
	b. Width of staircases			
	• Upper Floors	NA	NA (GF)	NA
	• Basements	NA	NA	NA
	c. Protection of exits.			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2 X 1.5 m	Provided 2 & 1.6 m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	05 Nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

SM

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	Provided	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	1 Nos.	Provided	MR
	• Hose Box	1 Nos.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

4/13

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	> Total Area	NA	NA	NA
	> Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire fighting arrangements provided in the building/restaurant were checked & found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/EH/MN/2021/105 dated 20/04/2021 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

118/ADO/MN
06/5/2024

Sir no punney

[Signature]
06/05/2024

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

[Signature]
06/5/2024

[Signature]
8/5/24

DCFO-253
8/5/2024

[Signature]
8/5/24

[Signature]
8/5/24

[Signature]
9/5/24

[Signature]

Sir, F. T is put up for your kind personal & signature please. *[Signature]*
13/5/2024