



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**



No F 6 / DFS / MS / 2024 / Hospital / 327

Dated 30/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **MAX Super Speciality Hospital** located at **FC-50, Shalimar Bagh, Delhi-110088** comprised of **02 Basements + Ground + 09 upper floors** owned/ occupied by **A Unit of Max Health Care Institute Ltd.** was issued Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/WZ/Hospital/2021/465** dated **24/09/2021**. The said Hospital building was re-inspected by the officer concerned of this department on **16.04.2024** in the presence of **Sh. Jitender Kumar Yadav (Dy. GM, Corporate Affairs) & Sh. Anit Kumar (Fire Safety Officer)** and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the building is fit for occupancy **Class Institutional "Group C"** with effect from **30/05/2024** for a period of **03 (Three) years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on **30/05/2024** at New Delhi by

(Anil Garg)

Director

Ph- 011-23414000

*Anil Garg*

Copy to:-

1. Dr. Girja Ruge Yadav (Head Operations), MAX Super Specialty Hospital, FC-50, Shalimar Bagh, Delhi-110088.
1. The Deputy Director (Bldg), DDA Building Section, C- 1<sup>st</sup>, 2<sup>nd</sup> floor, Vikas Sadan, New Delhi.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. 6 m road for movement of fire tenders all around the building shall be kept free from any hindrance.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**
9. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
10. The basement shall be used as per BBL.

**INSPECTION REPORT**

1. Name & address of the building : MAX Super Specialty Hospital (A Unit of Max Health Care Institute Ltd.)  
Located at FC- 50, Shalimar Bagh, New Delhi- 110088.
2. Type of Occupancy : Hospital (Institutional)
3. Building Comprised of : 02 Basements + Ground + 09 upper floors.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/WZ/Hospital/2021/465 Dated - 24/09/2021
6. Fire Safety directives letter No : F6/DFS/MS/BP/2009/2635 Dated- 26/08/2009
7. Date of inspection : 16 /04/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers  
From the building side : Sh. Jitender Kumar Yadav (Dy. GM, Corporate Affairs) &  
Sh. Anit Kumar (Fire Safety Officer)
10. Year of Construction : 2008/ 09
11. Applicant's letter No. : Form J dated 28/03/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL Requirements/ letter dated 24/09/2021	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	12 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	06 Staircase up to 3 <sup>rd</sup> floor out of which 4 staircase from 4 <sup>th</sup> to 9 <sup>th</sup> floor	Provided	MR
	• Basements	06	Provided	MR
	b. Width of staircases			
	• Upper Floor	2 m	Provided	MR
	• Basements	2 m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	2.4 m	Less than 2.4 m at some places	MR(old case)
	f. Door Size	2 m	Some doors are less than 2 m	MR(old case)
3.	<b>Compartmentation</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4.	<b>Smoke Management System</b>			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	165 Nos.	186 Nos.	MR
	• Types	DCP & Co2 Type	Provided	MR
	• IS marking	Required	Provided	MR

6.	<b>First-Aid Hose Reels</b>		Provided	MR
	• Total numbers on each floor in each block	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	
7.	<b>Automatic fire detection and alarming system</b>			MR
	• Type of detectors	Smoke/ Heat	Provided	MR(old case)
	• Location of Main Panel	Second basement	Provided	MR
	• Location of Repeater Panel	Each floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided at strategic locations	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	
10.	<b>Automatic Sprinkler System</b>			MR
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	NA
	• Sprinkler above false ceiling	NA	NA	
11.	<b>Internal Hydrants</b>			MR
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	Required	Provided	
12.	<b>Yard Hydrants</b>			MR
	• Total number of hydrants	06	Provided	MR
	• Hose Box	06	Provided	
13.	<b>Pumping Arrangements</b>			
	• Basement			
	➢ Discharge of main Pump	2280 lpm	Provided	MR
	➢ Head of Main pump	120 m	Provided	MR
	➢ Number of main pumps	2	Provided	MR
	➢ Jockey Pump out put	180 lpm	Provided	MR
	➢ Jockey pump head	120 m	Provided	MR
	➢ Standby Pump out put	2280 lpm	Provided	MR
	➢ Standby Pump Head	120 m	Provided	MR
	➢ Auto Starting/Manual Stopping	Required	Provided	MR
	➢ Pump House Access	Required	Provided	MR
	• Terrace level			
	➢ Discharge of pump	900 lpm	Provided	MR
	➢ Head of the pump	70 m	Provided	MR
	➢ Power Supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	200,000 ltrs	Provided	MR
	➢ Draw-off connection	Required	Provided	MR
	➢ Fire service inlet	Required	Provided	MR
	➢ Access to tank	Accessible	Accessible	MR
	• Overhead Tank capacity	20,000 ltrs	Provided	MR

	Required	Provided	MR
<b>Exit Signage.</b>			
<b>Provision of Lifts.</b>			
• Pressurization of Lift Shaft	Required	Provided	MR
• Pressurization of Lift lobby	Required	Provided	MR
• Communication In lift Car	Required	Provided	MR
• Fireman's Grounding Switch	Required	Provided	MR
• Lift Signage	Required	Provided	MR
17. Standby power supply	Required	Provided	MR
<b>18. Refuge Area.</b>			
> Total Area	106.56 Sqm each	Provided	MR
> Location	5 <sup>th</sup> & 7 <sup>th</sup> floor	Provided	MR
<b>19. Fire Control Room</b>			
• Detector System Panel	Required	Provided	MR
• Flow Switch Panel	Required	Provided	MR
• PA System Panel	Required	Provided	MR
• Battery backup	Required	Provided	MR
• Building Floor Plans	Required	Provided	MR
20. Special Fire Protection System for Protection of special Risks, if any:	Required	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to grant Fire Safety Certificate under rule 37 of the Delhi Fire Service Rules, 2010.

*(Signature)*  
24/5/24

Signature of Inspecting Officer  
Name: Rajeev Kumar Sinha  
Designation: ADO (BW)

*(Signature)*  
27/5/2024

*(Signature)*  
27/5/2024

*(Signature)*

After 45 days file is being sent for sign/approval after inspection.

*(Signature)*  
28/5/2024

Pls clarify above, why it took 45 days.

*(Signature)*

*(Signature)*  
27/5

Ado (Banjara) Sr. of F T letter is per...  
*(Signature)*

Sl. No. 802  
Date: 27/5/2024

23/5/24