

c93

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2024/ 151

Dated: 16/05/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Malhotra Guest House situated at 2911, Sir Seyed Ahmed Road, Darya Ganj, Delhi, comprised of Ground + 04 upper floors, ground floor- (commercial use), 1st floor - (reception + 09 guest rooms), 2nd floor - (11 guest rooms), 3rd floor & 4th floor - (owner's personal use), total 20 guest rooms owned/ occupied by Malhotra Guest House was granted FSC by this department vide letter no. F6/DFS/MS/GH/NDZ/2020/104 dated 18.03.2020. The building/ premises was re-inspected by the officer concerned of this department on dated 07.05.2024 in presence of Mohd. Qamar Ali Khan (Owner) and found that the building is comprised of ground + 04 upper floors and now the floor wise occupancy is ground floor- (commercial use), 1st floor - (reception + 09 guest rooms), 2nd floor- (11 guest rooms), 3rd floor- (owner personal use) & 4th floor - (not in use as per affidavit dated 08.05.2024). The building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of "Residential (Sub Division-A-1), 1st floor - (09 guest rooms) & 2nd floor - (11 guest rooms), total 20 guest rooms upto 2nd floor only, with effect from16/05/2024... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on ...16/05/2024...at New Delhi by


(Atul Garg)
Director

Delhi Fire Service o/c
Tel: 011-23414000
16/5

Copy to:-

1. The Commissioner, MCD:- to kindly ensure the occupancy as detailed above & deviation, if any.
2. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2023050908472 dated 22.04.2024.
3. The Licensee, M/S Malhotra Guest House at 2911, Sir Seyed Ahmed Road, Darya Ganj, Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
9. The occupancy of above 3rd floor not allowed as per clause 7.31 in UBBL-2016.

INSPECTION REPORT

1	Name & address of the building	M/s Malhotra Guest House at 2911, Sir Seyed Ahmed Road, Darya Ganj, Delhi.		
2	Building is comprised of	(Ground + 04 upper floors) Ground floor - (commercial use) 1 st floor - (reception + 09 guest rooms) 2 nd floor - (11 guest rooms) 3 rd floor - (owner's personal use) 4 th floor - (not in use as per affidavit dated 08.05.2024)		
3	Type of occupancy	Residential Group A-1		
4	Type of case	Renewal (old case)		
5	Details of previous FSC	F6/DFS/MS/GH/NDZ/2020/104 dated 18.03.2020		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	07.05.2024		
8	Name of the inspecting officers	Sumit Kumar, ADO (SPM)		
9	Name of the designation of officer from the building side	Mohd. Qamar Ali Khan (Owner)		
10	Year of construction	1982		
11	Applicant's letter no.	Online application I.D. No. 2023050908472 dated on 22.04.2024		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/ NMR
1	Access To Building:			
	Road width	NA	05 mtr. ✓	NA
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
	a	Upper floor	01 no.	01 no. ✓ MR
	b	Basement	NA	NA NA
B	Width of staircases			
	a	Upper floor	90 cms.	90 cms. ✓ MR
	b	Basement	NA	NA NA
C	Protection of exits			
	a	Fire check door	Required	Provided MR
	b	Pressurization	NA	NA NA
D	No. of continuous staircases to terrace		01 no.	01 no. ✓ MR
E	Width of corridor		NA	NA NA
F	Door size		1.0 mtr.	1.0 mtr. ✓ MR
3	Compartmentation:			
A	Fire check door		NA	NA NA
B	Sealing of electrical shafts		NA	NA NA
C	Fire rating of shaft door		NA	NA NA
D	Water curtain		NA	NA NA
E	Fire dampers		NA	NA NA
4	Smoke Management System:			
A	Basement		NA	NA NA
B	Upper floor		NA	NA NA

5.	Fire Extinguisher:				
	A	Total numbers	07 nos.	07 nos. ✓	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	Required	Provided	MR
6	First-Aid-Hose Reels:				
	A	Total numbers of each floor	1 no.	01 no. (MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	C	Nozzle diameter	05 mm	05 mm ✓	MR
7	Automatic Fire Detection And Alarming System:				
	A	Type of detectors (CO type)	Required	Provided	MR
	B	Location of main panel	Required	Provided at / 1 st floor	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	Required	Provided	MR
	E	Hooters	Required	Provided	MR
8	MOEFA:		NA	NA	NA
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants:				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements:				
	A	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
	B	Terrace level			
	a)	Discharge of pump	225 LPM	225 LPM ✓	MR
	b)	Head of the pump	30 mtrs.	30 mtrs. ✓	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage For Fire Fighting:			
	A	Underground tank capacity	NA	NA
	B	Draw-off connection	NA	NA
	C	Fire service inlet	NA	NA
	D	Access to tank	NA	NA
	E	Overhead tank capacity	5000 ltrs.	5000 ltrs. ✓ MR
15	Exit Signage:		Required	Provided MR
16	Provision of Lifts:			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:		Required	Provided MR
18	Refuge Area:			
	A	Total area	NA	NA
	B	Location	NA	NA
19	Fire Control Room :			
	A	Detector system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	Pa system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plans	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2020/104 dated 18.03.2020 is recommended to be renewed upto 2nd floor only, under Rule 35 of the Delhi Fire Service Rules, 2010.

Sumit Kumar
08/05/2024

Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (CD)
8/5/24

Dy. C.F.O. (NDZ)
10/5/2024

C.F.O. Singh
10/5/2024

Director
14/5/24

ANUSON