



FIRE SAFETY CERTIFICATE

Certified that the M/s Moyo Unit of Yakhi Distribution Private Limited running at first floor of building comprised of Ground, Mezzanine & Concourse (PD Area) located at Unit No. 108, First Floor, Station Box Area (PD Area), Dilshad Garden Metro Station, Delhi - 110095 owned/ occupied by M/s Moyo Unit of Yakhi Distribution Private Limited was granted FSC vide letter no. F6/DFS/MS/EH/2021/NDZ/84 dated 05/04/2021. The premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and re-inspected by the officer concerned of this department on 10.05.2024 in the presence of Mr. Shailander Sharma (Caretaker) and found that the restaurant building is fit for occupancy class "Assembly Building" (Group D) restaurant running at first floor only and valid up to 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued 16/05/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE

Copy to:-

1. The Manager, Moyo Unit of Yakhi Distribution Private Limited located at Unit No. 108, First Floor, Station Box Area (PD Area), Dilshad Garden Metro Station, Delhi - 110095.
2. The Joint Commissioner of police (Lic.), Ist Floor, P.S Defence Colony, New Delhi-24 w.e.f. - MHA portal ID - 2024042205807 dated 02/05/2024.

Conditions for the validity of Fire Safety Certificate:

1. Fire Safety Certificate is valid for first floor only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any..
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	M/s Moye Unit of Yakhi Distribution Private Limited Ltd. Located at Unit No 108, First Floor, Station Box Dilshad Garden Metro Station, Delhi -110095.
2	Building is comprised of	Ground, Mezzanine & Concourse (PD Area) (Restaurant running at first floor in PD Area)
3	Type of occupancy	Assembly (Restaurant)
4	Type of case	Renewal
5	Details of previous FSC	F6/DFS/MS/EH/2021/NDZ/84 dated 05/04/2021
6	Fire safety direction letter no.	NBC Part-IV
7	Date of inspection	10.05.2024
8	Name of the inspecting officers	Yashwant Singh Meena (ADO/LN)
9	Name of the designation of officer From the building side	Mr. Shailander Sharma (Caretaker)
10	Year of construction	2007-2008
11	Applicant's letter no	MHA Application No. 2024042205807 dated 02/05/2024.

S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
a	Road width	06 mtrs.	18 mtrs ✓	MR
b	Gate width	N/A	N/A	N/A
c	Width of internal road	N/A	06 mtrs	MR
2	Number, Width, Type and Arrangement of Exits			
A	Number of staircases			
a	Upper floor	02 nos	03 nos.	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	02 mtrs	3.47 mtrs x 2 & 1.35 mtrs	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	Provided	MR
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no	02 nos ✓	MR
E	Width of corridor	N/A	N/A	N/A
F	Door size	02 mtrs.	02 mtrs. ✓	MR
G	No of doors	02 nos.	02 nos. ✓	MR
3	Compartmentation			
a	Fire check door	N/A	N/A	N/A
b	Sealing of electrical shafts	N/A	N/A	N/A
c	Fire rating of shaft door	N/A	N/A	N/A
d	Water curtain	N/A	N/A	N/A
e	Fire dampers	N/A	N/A	N/A
4	Smoke Management System.			
a	Basement	N/A	N/A	N/A
b	Upper floor	Required	Natural Ventilated	MR

5.	Fire Extinguisher				
	a	Total numbers	04 nos.	06 nos.	MR
	b	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	c	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.				
	a	Total numbers	01 no.	01 no.	MR
	b	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	c	Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system.				
	a	Type of detectors	N/A	N/A	N/A
	b	Location of main panel	N/A	N/A	N/A
	c	Location of repeater panel	N/A	N/A	N/A
	d	Alternate source of power	N/A	N/A	N/A
	e	Hooter	N/A	N/A	N/A
8	MOEFA		Required	Provided	MR
9	Public address System.		Required	Provided	MR
10	Automatic Sprinkler System.				
	a	Basement	N/A	N/A	N/A
	b	Upper floors	Required	Provided	MR
	c	Sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants		Common with the Mall		
	a	Size of riser	100 mm	150 mm	MR
	b	Number of hydrants per floor	01 no.	01 no.	MR
	c	Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.				
	a	Total number of hydrants	NA	14 nos.	MR
	b	Hose Box	NA	14 nos.	MR
13	Pumping Arrangements.		Common With Metro Station		
	A	Ground Level			
	a	Discharge of main Pump	2850 LPM	2850 LPM x 2 & 1800 LPM	MR
	b	Head of Main Pump	70 m	70 m	MR
	c	Number of main pumps	01 no.	03 no.	MR
	d	Jockey pump out put	225 LPM	225 LPM	MR
	e	Jockey pump head	70 m	70 m	MR
	f	Standby pump out put	2850 LPM	2850 LPM	MR
	g	Standby pump head	70 m	70 m	MR
	h	Auto starting /manual stopping	Required	Provided	MR
	i	Pump House Access	Required	Provided	MR
	B	Terrace Level			
	a	Discharge of pump	N/A	N/A	N/A
	b	Head of the Pump	N/A	N/A	N/A
	c	Power supply	N/A	N/A	N/A
	d	Auto Starting of pump	N/A	N/A	N/A

M/s Moye Unit of Yakhi Distribution Private Limited Ltd. Located at Unit No 108, First Floor, Station Box Dilshad Garden Metro Station, Delhi-110095.

W

W

14	Captive Water Storage for Fire Fighting.		Common with Metro Station	
	a	Underground tank capacity	2, 00,000 liters.	2, 00,000 liters. ✓ MR
	b	Draw-off connection	Required	Provided MR
	c	Fire service inlet	Required	Provided MR
	d	Access to tank	Required	Provided MR
	e	Overhead Tank capacity	N/A	N/A N/A
15	Exit Signage.		Required	Provided ✓ MR
16	Provision of Lifts.			
	a	Pressurization of Lift Shaft	N/A	N/A N/A
	b	Pressurization of Lift lobby	N/A	N/A N/A
	c	Communication in lift car	N/A	N/A N/A
	d	Firemen's grounding switch	N/A	N/A N/A
	e	Lift Signage	N/A	N/A N/A
17	Standby power supply		N/A	Provided MR
18	Refuge Area.			
	a	Total area	N/A	N/A N/A
	b	Location	N/A	N/A N/A
19	Fire Control Room			
	a	Detector system panel	N/A	N/A N/A
	b	Flow switch panel	N/A	N/A N/A
	c	PA system panel	N/A	N/A N/A
	d	Battery backup	N/A	N/A N/A
	e	Building Floor Plans	N/A	N/A N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A N/A

Note: - Previous restaurant was running name of M/s Barshala (A unit of Indospirit Bars Pvt. Ltd. at same address now owner and name of restaurant has been changed.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC was issued vide letter no. F6/DFS/MS/EH/2021/NDZ/84 dated 05/04/2021 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

No file pending with me before disposal of this case.

DY. CFO/NDZ

Handwritten signatures and dates:
 C.F.O. *[Signature]*
 Director *[Signature]*
 15/5/20
 14/5/24

[Signature]
 13/5/2024
 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (L.N)

[Signature]