



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Institute/SZ/2024/ 330

Dated: 30/05/2024

FIRE SAFETY CERTIFICATE

Certified that the **State Council of Educational Research & Training** located at Varun Marg, Defence Colony, New Delhi-110024, comprised of Ground Floor & First Floor [New Block (SPS)] only, owned/occupied by State Council of Educational Research & Training was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/Educational/2021/11 dated 08/01/2021. The said premises was re-inspected by the officer concerned of this department on 22/05/2024 in the presence of Mr. B.B. Karan (Estate Manager) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in according with Director of Education Circular No. F.16/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building/premises is fit for occupancy class "**Educational**" (Group-B) with effect from the date of issuance for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/05/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Dr. Mukesh Yadav, Secretary/HOO, State Council of Educational Research & Training, Varun Marg, Defence Colony, New Delhi-110024.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

N-18

INSPECTION REPORT

1.	Name & address of the building	State Council of Educational Research & Training, Varun Marg, Defence Colony, New Delhi-110024		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	Two interconnected blocks of Ground + One Upper Floor [New Block, SPS]		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/Educational/2021/11 Dt. 08/01/2021		
6.	Fire Safety Directives Letter No.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
7.	Date of inspection	22/05/2024		
8.	Name of the Inspecting Officer	Santosh Kumar (ADO/SJ)		
9.	Name and designation of Officer from the building side	Mr. B.B. Karan (Estate Manager)		
10.	Year of Construction	2019 - 20		
11.	Applicant's letter No	Outdoor Diary No. 468 dated 10/04/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular Dt. 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	6 mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos	2 Nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.50m x 2nos	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	1m	1m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	04 Nos	10 Nos	MR
	• Types	ABC / CO ₂	ABC& CO ₂	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA

80

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detector Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE Circular dated 01.03.2011, the Fire Safety Certificate issued vide letter No. F6/DFS/MS/Educational/2021/11 dated 08/01/2021, renewal under rule 37 of Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S. Kumar
22.05.24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

~~DO (SD)~~

ms
24/5/24

CP *Wagh*
24/5/24

Director
24/5/24

MS

Sir,

F.T letter is put up for your sig. pl.

Director
29/5/24

S. Kumar
29/05/24