



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No: F.6/DFS/MS/WZ/EH/2024/ 151

Dated: 17/05/2024

FIRE SAFETY CERTIFICATE

Certified that Ms. The Firangi Grill, located Shop/property No: - 62, Ground Floor, Rama Road, Najafgarh Road, New Delhi-110015, in a building comprised of ground floor only. Owned/occupied by M/s. The Firangi Grill, was issued Fire Safety Certificate vide Letter No. F6/DFS/MS/EH/MN/2021/161 dated 29/07/2021, The premises was re-inspected by officer concerned of this department on 13/05/2023 in the presence of Sh. Ankur Aggarwal and found that the said building/Premises have deemed complied with the fire prevention & fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rule 2010 & the said premises is fit for occupancy class "Assembly" Group - D (Ground Floor Only) valid upto 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions Printed Overleaf.

Issued on 17/05/2024 at New Delhi by.

(Atul Garg)
Director

15/8
14/05/2024

Copy to: -

1. The Owner/Occupier, Ms. The Firangi Grill, located Shop No: - 62, Ground Floor, Rama Road, Najafgarh Road, New Delhi-110015.
2. The Joint Commissioner of Police, Licensing Unit, 1st Floor, Defence Colony Police Station, New Delhi.
3. The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi- 110027. (dhowest zone@gmail.com).

N/15
INSPECTION REPORT

1. Name & address of the building	The Firangi Grill located at Shop No. 62, Ground floor, Rama Road, Najafgarh Road, New Delhi-110015.
2. Type of Occupancy	Assembly
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/EH/MN/2021/161 dated 29/07/2021
5. Fire Safety directives letter No	Nil
6. Date of inspection	13/05/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Ankur Aggarwal
9. Year of Construction	1977 (As per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2021092722660 & 2024032803741 dated 26/03/2024

*** The Said Restaurant is running at ground floor in a building comprised of ground floor only.**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	Provided	MR
	• Gate width	05m	Provided	MR
	• Width of internal road	NA	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA (G.F.)	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA (G.F.)	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2m & 1.5 m	1 x 210cm & 1 x 153cm Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	05 Nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	Smoke Provided	NA
	• Location of Main Panel	NA	GF	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	Provided	NA
	• Hooters' Location	NA	Near Exit	NA
8	MOEFA			
		Required	Provided	MR
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000ltr	Provided	MR
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection. The shortcoming issued by this department vide letter no. F6/DFS/MS/WZ/EH/2024/139 dated 19/04/2024 have been complied.

22/ADO/MN
14/05/2024

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/EH/MN/2021/161 dated 29/07/2021, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Sir, w pending

~~DCFO (WZ)~~

~~14/05/2024~~

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

DCFO/265-MN/A
Dated..15/05/2024

~~15/5/2024~~

~~CFO~~
~~16/5/2024~~
~~Director~~
~~17/5/24~~
~~W~~

Uploaded
21/05/24

