

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/Hostel/2024/SZ/184

Dated: ..27/05/2024

FIRE SAFETY CERTIFICATE

Certified that M/s "Adya Jha Hostel" located at C-3, Safdarjung Development Area, Hauz Khas, New Delhi-110016 comprised of ground plus three upper floors (Hostel Block) & ground plus one upper floor (Admn Block), owned/occupied by M/s Young Women's Association (Regd.) was issue FSC by this department vide letter No. F.6/DFS/MS/Hostel/2019/SZ/1080 dated 25/05/2019. The premise was re-inspected by officer concerned of this department on 17/05/2024 in the presence of Mr. Suresh Chandra (Accts Officer) and observed that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for (**Ground floor: 12 Rooms, First floor: 12 Rooms, Second floor: 12 Rooms, Third floor: 12 Rooms, Total= 48 Rooms**) occupancy class **Group-A, Residential (Hostel Building)** as above with effect from 27/05/2024 for period of **Five years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 27/05/2024 at New Delhi by


**(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE**

Copy to: -

1. The Addl. Commissioner of Police (Lic.), Ist Floor, P.S. Defence Colony, New Delhi-110049
2. Ms. Madhubala (Hony. Gen. Secretary), Young Women's Association (Regd.), Block C-3, Safdarjung Development Area, Hauz Khas, New Delhi-110016

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (l) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/27

INSPECTION REPORT.

1	Name & Address of the Building	M/s Adya Jha Hostel at C-3, Safdarjung Development Area, Hauz Khas, New Delhi - 110016 [Young Women's Association (Regd.)]		
2	Type of Occupancy	Residential, "Group-A" (Hostel Building)		
3	Building Comprised of	G + 3 (Hostel Blk) & G + 1 (Admn Blk)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Hostel/2019/SZ/1080 dated 25-05-2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	17-05-2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Suresh Chandra (Accts Officer)		
10	Year of construction	1965	Gd. floor (12 rooms), 1 st floor (12 rooms), 2 nd floor (12 rooms) and 3 rd floor (12 rooms), Total- 48 rooms	
11	Applicant letter No.	Outdoor diary no 1477 dated 08-05-2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	9 mtr	MR
	• Gate width	Required	4 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 each in Blk	02 each in block	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.25m / 0.90m	Hostel Blk-1.10m each Admn Blk-1.10m & 1.04m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	01 each Bk	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	1m provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	ISI marked	30 Nos	MR
	• Types		ABC, Co2 & W.Co2	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose-reels	02 each floor	MR
	• Length of hose-reel hose.		30m	MR
	• Nozzle Diameter		5mm	MR

M/s Adya Jha Hostel at C-3, Safdarjung Development Area, Hauz Khas, New Delhi-16

2/28

7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8	MOEFA	Required	Provided & functional	MR
9	Public Address System	Required	Provided & functional	MR
10	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	• Size of Riser/Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
12	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	450 & 180 LPM	MR
	➤ Head of pump.	40m	40m each	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	5,000 Ltr	5,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided (DG Set)	MR
18	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

19	Fire Control Room.	• Detector system panel.	-NA-	-NA-	-NA-
		• Flow switch panel.	-NA-	-NA-	-NA-
		• PA system panel.	-NA-	-NA-	-NA-
		• Battery backup.	-NA-	-NA-	-NA-
		• Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.			-NA-	

M/s Adya Jha Hostel at C-3, Safdarjung Development Area, Hauz Khas, New Delhi-16

The Fire protection systems provided in the building/ premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/Hostel/2019/SZ/1080 dated 25-05-2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Handwritten signature]

Signature of the Inspecting Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

[Handwritten signature]

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HO)

[Handwritten signature]
21/5/2019
Director *[Handwritten signature]*
22/5/19

[Handwritten signature]

As approved, F-1. Letter is
forwarded for your signature P/

1/25
24/5

[Handwritten signature]
Director *[Handwritten signature]*
24/5/19

[Handwritten signature]