

C 78

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2024/168

Dated : 21/05/2024

FIRE SAFETY CERTIFICATE

Certified that the **Delhi Heart Guest House** located at **3738, Dariba Pan, Pahar Ganj, New Delhi** comprised of Basement + Ground + 04 Upper floors, Basement (Store), Ground floor (Reception + other portion), 1st floor to 3rd floor (08 guest rooms at each floor) and 4th floor not in use as per affidavit dated 10.12.2019, total 24 guest rooms up to third floor only owned/occupied by Delhi Heart Guest House was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2021/222 dated 16/07/21. Now, the premises was re-inspected by the officer concerned of this department on 13/05/24 in the presence of **Sh. Ram Kumar** (Manager) and found that the said guest house building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub Division-A-1 basement (storage), Ground floor (Reception), 1st floor to 3rd floor (08 guest rooms at each floor), total 24 guest rooms up to third floor only** and valid up to **31.03.2027** from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 21/05/2024 at New Delhi by.


Anul Garg
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, North MCD, Civic Centre, and New Delhi: to ensure not to use any floor above third floor for any purpose and deviation if any.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. Online id no.2024042706293 dated: 27/04/24.
3. The Manager, Delhi Heart Guest House at 3738, Dariba Pan, Pahar Ganj, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

N/25

INSPECTION REPORT

1. Name & address of the building **Delhi Heart Guest House at 3738, Dariba Pan, Pahar Ganj, New Delhi**
2. Type of occupancy:- **Residential, Sub Division-A-1
B + Ground + 04 Upper floors (total 24 guest rooms)
Basement (Store), Ground floor (Reception + other portion
1st floor to 3rd floor (08 guest rooms at each
floor) and 4th floor not in use as per
affidavit dated 10.12.19**
3. Type of case:- **Renewal**
4. Details of previous FSC:- **No.F6/DFS/MS/GH/NDZ/2021/222 dated
16/07/21**
5. Fire safety directives No.- **N/A**
6. Date of inspection:- **13/05/24**
7. Name of the inspecting officer:- **Sh. Ravinder Singh (ADO/CC)**
8. Name & designation of officer
From the building side:- **Mr. Ram Kumar (Manager)**
9. Year of construction:- **2009**
10. Applicant's letter No:- **ID No. 2024042706293 dated: 27/04/24.**

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	9 mtr. ✓	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos. ✓	MR
	2. Basements	01 Nos.	01 Nos. ✓	MR
	B. Width of staircase			
	1. Upper floors	1.25 mtr.	1.47 mtr. ✓	MR(old case
	2. Basements	1.25 mtr.	1.47 mtr. ✓	MR(old case)
	C. Protection of exits			
	1. Fire check door	Required	Provided ✓	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	01 mtr.	01 mtr. ✓	MR
	F. Door size	01 mtr.	01 mtr. ✓	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	Required	Natural /exhaust fan	MR
5.	Fire Extinguishers			

11/26


	1) Total numbers	12 Nos.	15 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO Type	Required	Provided	MR
	2) Location of main panel	Ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Ground floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement(Less than 189 SQM)	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 & 180 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A







	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10000 ltr.	10000 ltr. ✓	MR
15.	Exit Signage.	Required	Provided ✓	MR
16.	Provision of Lifts.			N/A
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	MR
17.	Stand by Power Supply	Required	Provided ✓	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2021/222 dated 16/07/21, under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer


 Name: - Ravinder Singh
 Designation: - ADO (CC)



 16/5/24


 C.F.O. 
 17/5/24
 Director 
 17/5/24
 ADO/CA 