

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

Dated: 13/05/2024

No.F6/DFS/MS/SZ/2024/143

FIRE SAFETY CERTIFICATE

Certified that the M/S Drink 'N' Dine Restaurant, Located at, 3rd floor Supreme Plaza, Shop No. 5,6,7, Plot No. 15-16, Sector - 6, Dwarka, New Delhi - 110075, in a building comprised of Ground + 03 Upper Floors FSC issued vide letter no F6/DFS/MS/SZ/2021/259, dated 29/09/2021. The premises was re - inspected by the officer concerned of this department on 07/05/2024 in the presence of Mr. Anil Negi (Manager) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010, and that the building is fit for occupancy class " Assembly" Group D (at 3rd floor only) with effect from 13/05/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/05/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service


Copy to:

1. The Joint. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Manager, M/S Drink 'N' Dine Restaurant, Located at 3rd floor Supreme Plaza, Shop No. 5,6,7, Plot No. 15-16, Sector - 6, Dwarka, New Delhi - 110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N-35

INSPECTION REPORT

1. Name & address of the building: M/S Drink 'N' Dine Restaurant, Located at 3rd floor Supreme Plaza, Shop No. 5,6,7, Plot No. 15-16, Sector - 6, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Class-D (Assembly)(Running At 3rd Floor in a building comprised of Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC :F6/DFS/MS/SZ/2021/259, dated 29/09/2021
5. Fire Safety directives Letter No. :Nil
6. Date of inspection : 07/05/2024
7. Name of the Inspecting Officer ; Sh. Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Anil Negi (Manager)
9. Year of Construction : Before 2006
10. Applicant's L. No: Application No. 2024031202903, dated 15/04/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/17, N/18 & N/19	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtrs	Provided	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Old case	01	MR(Old case)
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.25 mtr	1.25 mtr	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01	MR
	e. Width Of Corridor	1.42 m	1.42 mtr	MR
	f. Door Size	90 cm X210 cm	02 mtr(Including door Frame) & 90 cm	MR(Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Provided in kitchen	MR



2-38

5.	Fire Extinguishers	03 Nos. ABC, CO2 ISI marked	04 Nos. ABC, CO2 Provided	MR MR MR
6.	First - Aid Hose Reel	01 No	01 No	MR
	• Total numbers on each floor	30 mtr	30 mtr	MR
	• Length of hose reel hose	5 mm	5 mm	MR
	• Nozzle diameter			
7.	Automatic fire detection and alarming system	Required	Smoke/ Heat	MR
	• Type of detectors	Required	Near main gate	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	Required	DG set 62.5 KVA	MR
	• Alternate source of power	Required	Near main gate	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	NA	NA	NA
	• Basements	Required	Provided in restaurant area	MR
	• Upper Floor			
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:	100 mm	100 mm	MR
	• Size of riser/down- comer	01 at 3 rd floor	01 at 3 rd floor	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box			
12.	Yard Hydrants	NA	NA	NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box			
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180 lpm	450 lpm & 180 lpm	MR
	➤ Head of the pump	30 m	30 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	Old case	5,000 ltr	MR
15	Exit Signage	Required	Provided	MR

Provision of Lifts				
16.	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/SZ/2021/259, dated 29/09/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~
 Name Uday Vir Singh
 Designation AO/NEA

DO/SEC
 08/16/24

CFO (S2)
8/5/2024
Director (M)
9/5/24

AO/NEA

Uploaded
13/5/24

(Signature)