

No. F6/DFS/MS/School/WZ/2024/ 510

Dated:- 06/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **Blooming Dales Public School**, Located at **Rajender Park, Rohtak Road, Nangloi, Delhi-110041**, comprised of **Ground + 03 Upper Floors** owned/occupied by **Blooming Dales Public School**, was issued Fire Safety Certificate by this department Vide Letter No. **F6/DFS/MS/School/2021/311** dated **07/04/2021**. The said premise was re-inspected by the officer concerned of this department on **20/05/2024** in the presence of **Sh. Bhram Dev Dabas (Chairman)** and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17/01/2005 and that the premises/building is fit for occupancy class **“Educational Building” Group B** with effect from **06/06/2024** for a period of **three years** in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rules, 2010, printed below.

Issued on **06/06/2024** at New Delhi by.

(Abul Gafar)
Director

Tel. No 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Blooming Dales Pubic School, Rajendra Park, Rohtak Road, Nangloi, Delhi- 110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **Blooming Dales Public School, located at Rajendra Park, Rohtak Road, Nangloi, Delhi**
2. Type of Occupancy : Educational, (Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/311 dated 07/04/2021
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 262-362 dated 17/01/2005
6. Date of inspection : 20/05/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Bhram Dev Dabas (Chairman)
9. Year of Construction : 2006
10. Applicant's letter No. : email dated 01/05/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cr. No. 262-362 Requirements/as per FSC dated 07/04/2021		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	06 m	On main rohtak road		MR
	• Gate width	4.5 m	Provided		MR
	• Width of internal road	NA	NA		NA
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases	02	Provided		MR
	• Upper floors	NA	NA		NA
	• Basements				
	b. Width of staircases	1.5 m or less	1.30 m x 1.110 m		MR (Old Case)
	• Upper floors	for additional 0.75m	NA		NA
	• Basements				
	c. Protection of exits				
	• Fire check door	NA	NA		NA
	• Pressurization	NA	NA		NA
	d. No of continuous staircase to terrace	01	01		MR
	e. Width Of Corridor	1.5 m	1.5 m		MR
	f. Door Size	1.0 m	1.0 m		MR
3.	Compartmentation				
	• Fire check door	NA	NA		NA
	• Sealing of electrical shafts	NA	NA		NA
	• Fire Rating of shaft door	NA	NA		NA
	• Water Curtain	NA	NA		NA
	• Fire Dampers	NA	NA		NA
4.	Smoke managements System				
	• Basements	NA	NA		NA
	• Upper floors	NA	NA		NA
5.	Fire Extinguishers				
	• Total numbers	08 nos.	10 nos.		MR
	• Types	ABC & CO ₂	Provided		MR
	• IS marking	ISI marked	Provided		MR

6.	First - Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180 lpm	900 lpm & 180 lpm	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs.	5,000 ltrs.	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

1/20

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Cr. No. 262-362 dated 17/01/2005 renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2021/311 dated 07/04/2021 is recommended.

Accordingly DFA is put up for approval please.

~~DCPO (W/P)~~

Aman Kumar Lathar
36/05/24
Aman Kumar Lathar
ADO (JWP)

303/6/2024

3/6/2024

Director
303/6/24

ADO (JWP)

See, F.F. letter is added for your signature to.

Director
303/6/24

Aman Kumar Lathar
05/06/24
ADO (JWP)