


FIRE SAFETY CERTIFICATE

Certified that the CNG Dispensing Station located at Dilshad Garden, Delhi – 110095, Comprised of ground floor only, owned/occupied by **Indraprastha Gas Limited** was issued FSC vide letter no. F6/DFS/MS/CNG/2021/NDZ/292 dated 30/06/2021. The CNG station was re-inspected by the officer concerned of this department on 31/05/2024 in the presence of Mr. Sunchit Sehrawat (Manager Fire & Safety) and found that the CNG station have deemed fit for occupancy “CNG Filling Station” (Group – J) for ground floor with effect from 04/06/2024 for a period of **three years**, subject to conditions, printed overleaf.

Issued on 04/06/2024 at New Delhi by.


(APUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE
@

Copy to: -

1. The General Manager (Fire & Safety), IGL Bhawan, Plot No. 04, Community Center, R.K. Puram Sector - 09, New Delhi - 110022.

Conditions for the validity of Fire Safety Certificate

1. No trade susceptible to cause to CNG by generating head, mechanical/ electrical spark should be allowed within the licensed premises.
2. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipment, electrical gadgets and fitting in the premises shall conform to hazardous area classification for the at purpose and be of a type approved by the CCE.
3. In premises “NO Smoking” signs board both Hindi and English shall be displayed in such a manner as to be easily readable by all people.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. Noting contravention of the explosive Act. 1884 and rules their under 1983, and static mobile pressure vessels (Unfired) Rules 1981 as modified from time to time.
7. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. May be got verified from the concerned authorities..
8. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [Sub rule(1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT


1	Name & address of the building	CNG Dispensing Station located at Dilsad Garden, Delhi By IGL			
2	Building is comprised of	Ground floor			
3	Type of occupancy	CNG Storage & Dispensing Unit			
4	Type of case	Renewal			
5	Details of previous FSC	F.6/DFS/MS/CNG/2021/NDZ/292 dated 30/06/2021			
6	Fire safety directives letter no.	OISD-179			
7	Date of inspection	31/05/2024			
8	Name of the inspecting officers	Yashwant Singh Meena ADO/Laxmi Nagar)			
9	Name of the designation of officer from the building side	Mr. Sunchit Sehrawat (Manager Fire & Safety)			
10	Year of construction	2005			
11	Applicant's letter no.	Outdoor dairy no. 1604 dated 13/05/2024			
S.No	Minimum standard of fire prevention and fire safety U/R 33	As per Directives	Provided at site	Remarks MR/NMR	
1	Access to Building:				
	A	Road width	12 meters.	15 meters. ✓	MR
	B	Gate width	4.5 meters.	6.0 meters.	MR
	C	Width of internal road	N/A	N/A ✓	N/A
2	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases	N/A	N/A	N/A
	B	Width of staircases	N/A	N/A	N/A
3	Compartmentation:		Required	Provided	MR
4	Smoke Management System:		Required	Provided	MR
5.	Fire Extinguisher:				
	A	DCP Type 10 kg	15 nos.	29 nos. ✓	MR
	B	DCP Type 75 kg	03 nos.	11 nos. ✓	MR
	C	CO ₂ Type 4.50 kg	04 nos.	04 nos. ✓	MR
	D	ISI marking	ISI Marked	ISI Marked ✓	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	N/A	N/A	N/A
	B	Length of hose reel hose	N/A	N/A	N/A
	C	Nozzle diameter	N/A	N/A	N/A
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	Gas	Provided ✓	MR
	B	Location of main panel	Required	Provided	MR
	D	Alternate source of power	Required	Provided ✓	MR
	E	Hooters	Required	Provided	MR
8	MOEFA:		N/A	N/A ✓	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:		N/A	N/A	N/A
11	Internal Hydrants:		N/A	N/A	N/A
12	Yard Hydrants:		N/A	N/A	N/A
13	Pumping Arrangements:				
	A	Terrace Level	N/A	N/A	N/A
	B	Discharge of pump	N/A	N/A	N/A
	C	Head of the pump	N/A	N/A	N/A
	D	Power supply	N/A	N/A	N/A
	E	Auto starting of pump	N/A	N/A	N/A

14	Captive Water Storage for Fire Fighting			
15	Exit Signage/ No Smoking Signage	Required	provided	MR
16	Provision of Lifts	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
20	Special Fire Protection systems			
	A CO2, DCP local application	Required	Provided	MR
	B Hand held explosive meter	02 nos.	Provided	MR

The fire protection system provided in the CNG station were tested / checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety as per OISD-179, renewal of Fire Safety Certificate is recommended.

No file is pending with me before disposal of this case.



03/6/2024

Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO (Laxmi Nagar)


~~DY. CFO/NDZ~~

~~C.F.O.~~
~~3/6/2024~~
~~Director~~
~~3/6/24~~
~~3/6/24~~

Six.

F.T Letter is Aduy for sign. please

~~Director~~



4/6/2024