

c-38

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

**NEW DELHI-110 001.**

No. F.6/DFS/MS/EH/2024/SZ/ 172

Dated: 04/06/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Dasaprakash (A unit of Das Kitchens) located at R-1, S-1, S-2, Westend Convention Point, Plot No. -15-16, District Centre, Janakpuri, New Delhi-110058, comprised of basement, ground plus three upper floors but restaurant is running at ground floor, was issued FSC by this department vide letter no. F.6/DFS/MS/EH/2018/SZ/2151 dated 05.10.2018 in the name & style of M/s M/s Red Chilli (a unit of Red Chilli F & B Services), now owned/occupied by (Dasaprakash A unit of Das Kitchens) was re-inspected by the officers concerned of this department on 24.05.2024 in the presence of Sh. Kulwant Sharma and found that M/s Dasaprakash (A unit of Das Kitchens) have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (**Ground floor Only**) is fit for occupancy class Group-D "Assembly Building" w.e.f. 04/06/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 04/06/2024 at New Delhi.

  
(Atul Garg)  
Director  
Delhi Fire Service

**Online Application Id 2024050907259 dated 13.05.2024**

**Following fire safety directives must be adhered to: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building: M/s Dasaprakash A unit of Das Kitchens located at R-1, S-1, S-2, Westend Convention Point, Plot No. -15-16, District Centre, Janakpuri, New Delhi-110058
2. Type of Occupancy : Group D (Assembly Building)
3. Building Comprised of : Basement, ground plus three upper floors but restaurant is running at ground floor only.
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/EH/2018/SZ/2151 dated 05.10.2018
6. Fire Safety directives letter No : N/A
7. Date of inspection : 24.05.2024
8. Name of Inspecting Officers : D.O Vedpal Chhikara & A.D.O. R.K. Yadav
9. Name and designation of officers  
From the building side : Sh. Kulwant Sharma
10. Year of Construction : 2007
11. Applicant's letter No. : Online Application Id 2024050907259 dated 13.05.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible (09 mtrs) 4.5 mtrs N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>	(restaurant is running at GF)		
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtrs & 01 mtrs	200, 125 & 110 cms	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	<b>Smoke Management System</b>	(restaurant is running at GF)		
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Natural Ventilation	MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	06 No.'s ABC/ CO <sub>2</sub>	Provided	MR
			Provided	MR
		ISI marked	ISI marked	MR
6.	<b>First-Aid Hose Reels</b>			



N/17

	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	One 30 mtrs 5 mm	Provided Provided Provided	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A N/A N/A	N/A Provided N/A	N/A N/A N/A
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants</li> <li>Hose Box</li> </ul>	100 mm 01 No. 01 No.	Provided Provided Provided	MR MR MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A N/A	N/A N/A	N/A N/A
13.	<b>Pumping Arrangements (common with S.K. Westend Convention Centre)</b>			
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> <li>Pump House Access</li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	2280 LPM 60 mtrs One 180 LPM 60 mtrs 2280 LPM 60 mtrs Required N/A 900 LPM 40 mtrs Required Required	Provided Provided Provided Provided Provided Provided Provided Provided N/A Provided Provided Provided Provided	MR MR MR MR MR MR MR MR N/A MR MR MR MR
14.	<b>Captive Water Storage for fire-fighting (common with S.K. Westend Convention Centre)</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity                             <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	50,000 ltrs Required Required Required 15000 ltrs	Provided Provided Provided Provided 25000 ltrs provided	MR MR MR MR MR
15.	Exit Signage.	Required	Provided	MR
16.	<b>Provision of Lifts. (No Lift)</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A


15


		Required	Provided	MR
	Standby power supply			
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.


In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/2018/SZ/2151 dated 05.10.2018, renewal/grant under rule 37 of the Delhi Fire Service rules 2010 is recommended.

Note: - Earlier FSC was issued in the name & style M/s. Pind Balluchi-Grills & Platters (A unit of IKO Hospitality Pvt. Ltd.) and M/s Red Chilli (a unit of Red Chilli F & B Services) through vide letter no. F.6/DFS/MS/EH/2013/SZ/712 dated 14.08.2013, and letter No. F.6/DFS/MS/EH/2018/SZ/2151 dated 05.10.2018 respectively. M/s S.K. Westend Convention Centre building in which aforementioned restaurant is situated has already been issued FSC by this department vide Letter No. F6/DFS/MS/2018/SZ/1981 dated 29.08.2018.

  
 Signature of Inspecting Officer  
 Name: - R.K. Yadav  
 Designation: - ADO (JKP)

  
 Signature of Inspecting Officer  
 Name: - Vedpal Chhikara  
 Designation: - DO (SW)

C.F.O. (South Zone)

  
 Director  
 30/5/2019

  
 ADO (JKPDR)

  
 DO (SW)