



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/assembly hall /2024/ 351

Dated 11/06/2024

FIRE SAFETY CERTIFICATE

Certified that the **Assembly hall at Delhi Parsi Anjuman Premises** located at Bahadurshah Zafar Marg, Delhi Gate, New Delhi, comprised of basement and ground floor having hall for religious prayer at ground floor and basement for storage, was earlier granted FSC by this department vide letter No.F6/DFS/MS/assembly hall/2021/505 dated 14/10/2021. Now, the premises was re-inspected by the officers concerned of this department on **04/06/24** in the presence of Mr. Jai bhagwan and found that the said hall has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class – Assembly occupancy, **Assembly Hall at Ground floor** with effect from **11/06/2024**.....for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued **11/06/2024**.....at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

- 1) The Commissioner, Municipal Corp. of New Delhi.
- 2) Sh. Cyrus Engineer, The Joint Secretary, The Delhi Parsi Anjuman, Bahadurshah Zafar Marg, Delhi Gate, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned. Basement shall not be used for any purpose.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. The flammable material use for interior decoration, if any, shall strictly be prohibited.

118

INSPECTION REPORT

1.	Name & address of the building	Delhi Parsi Anjuman, Assembly Hall located at Bahadurshah Zafar Marg , Delhi Gate, New Delhi, building is comprised of basement and ground floor.
2.	Type of occupancy:-	Assembly Occupancy –Hall for assembly at ground floor.
3	Type of case:-	Renewal
4	Details of previous FSC:-	F6/DFS/MS/assembly hall/2021/505 dated 14/10/2021.
5	Fire safety directives No.-	N/A
6	Date of inspection:-	04.06.2024
7	Name of the inspecting officer:-	Sh. Ravinder Singh (ADO/CC) Sh. Rajinder Atwal (DO/CD)
8	Name & designation of officer From the building side:-	Mr. Jai bhagwan
9	Year of construction:-	NA
10	Applicant's letter No:-	Letter No nil dated 22.05.24

The basement is using for storage purpose and assembly hall at ground floor having no fixed seat, using for prayer.

Renewal old case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06mtr	06mtr. ✓	MR
	2) Gate width	05 mtrs	05 mtrs ✓	MR
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	02	02	MR
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	1.10 mtr & 0.75 mtr	1.10 mtr & 0.75 mtr ✓	MR (Old case)
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.65 mtr.(5 exit)	1.65 mtr (6 exit) ✓	MR
3.	Compartmentation			

	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	12 ACPH	Exhaust	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2 /	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number	02	02	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants	02Nos	Provided	MR
	3) Hose box	02Nos	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02nos	Provided	MR
	2) Hose box	02nos	Provided	MR
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A /	N/A
	a) Discharge of main pump	450 LPM	900 LPM /	MR
	b) Head of main pump	40mtr	40 mtr /	MR
	c) Number of main pump	01 nos	Provided /	MR
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	N/A	N/A	N/A

	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	10,000 ltr.	10,000 ltr. ✓	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply (DG Set)	Required	Provided ✓	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO²			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/assembly hall/2021/505 dated 14/10/2021, under rule 35(6) of the Delhi Fire Service rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Rajinder Atwal
27/6/24

Name: - Rajinder Atwal
Designation: -DO (CD)

Signature of the Inspecting Officer

Ravinder Singh
27/6/24

Name: - Ravinder Singh
Designation: - ADO (CC)

Dy. Ch. Insp.
[Signature]

Riv
25/06/24

C.F.O.
[Signature]
6/6/2024

Director
[Signature]

AMU
✓